Multi-Zone Indoor Unit Console



Model			MFAHU-H09B-2A	MFAHU-H12B-2A	MFAHU-H16B-2A
Performance					
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	441/377/324/188/130	441/377/324/188/130	500/441/383/324/206
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	45/41/38/26/22	44/41/37/27/24	47/44/41/31/26
Dimension & Weight					
Net Dimension	$W \times D \times H$	mm	794×200×621	794×200×621	794×200×621
Net Dimension	$W \times D \times H$	inch	31-1/4×7-7/8×24-1/2	31-1/4×7-7/8×24-1/2	31-1/4×7-7/8×24-1/2
Packing Dimension	$W \times D \times H$	mm	865×280×719	865×280×719	865×280×719
Packing Dimension	$W \times D \times H$	inch	34×11×28-1/4	34×11×28-1/4	34×11×28-1/4
Net/Gross Weight		kg	14.9/19.0	14.9/19.0	14.9/19.0
iver, 01033 Weight		lbs	33/42	33/42	33/42
Piping Size	Liquid side	inch	1/4	1/4	1/4
Tiping Size	Gas side	inch	3/8	3/8	1/2

Multi-Zone Indoor Unit Ceiling & Floor



Model	Indoor Unit		MFBHU-H18B-2A	MFBHU-H24B-2A
Performance				
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	577/547/486/421/ 421	736/706/606/453/377
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	45/43/40/31/29	52/49/45/34/29
Dimension & Weight				
Net Dimension	$W \times D \times H$	mm	1068×675×235	1068×675×235
Net Diffiension	$W \times D \times H$	inch	42×26-5/8×9-1/4	42×26-5/8×9-1/4
Packing Dimension	$W \times D \times H$	mm	1145×755×318	1145×755×318
Packing Dimension	$W \times D \times H$	inch	45-1/8×29-3/4×12-1/2	45-1/8×29-3/4×12-1/2
Net/Gross Weight		kg	26.5/32.0	27.8/33.2
Net/ Gloss Weight		lbs	58/71	61/73
Piping Size	Liquid side	inch	1/4	3/8
Fibility Size	Gas side	inch	1/2	5/8



Midea **DUCTED & DUCTLESS COMPATIBLE**

MULTI-ZONE SYSTEM

MEET THE MIDEA **NEW CENTRAL SYSTEM**















What Is A Multi-Zone System


A multi-zone system connects only one outdoor unit to multiple indoor units, so it's capable of cooling or heating multiple indoor rooms. Each indoor unit can also be individually controlled, scheduled and set to the desired room temperature.

Advantages of **Multi-Zone Systems**





Provide a wide selection of indoor unit capacities and styles to suit a variety of room sizes and designs.







Connect several indoor units to a single outdoor units, reduce installation space and outdoor noise.



DUCTED &

Add ductless units to the common ducted system.






Achieve lower system total power, fit well with the application that sets the power/current limit for air conditioners or home aplliances.



INDIVIDUAL CONTROL

Provide individual control for each indoor unit. Bring desired comfort and Save energy as you can heat or cool only those rooms you are using and not the entire house.

Ducted & Ductless



High Efficiency & Expandability

Inverter

With innovative inverter technology. Midea's multi-zone system can adjust the capacity output as the temperature changes, by controlling the operation of compressor and fan motors.

When not all rooms require air conditioning or when ambient temperature changes, it runs with partial load and lower energy consumption.



Expand your Existing Central Ducted System

Incorporating an AHU into the multi-zone system makes the system applicable to wider scenarios and conditions, allowing homeowners to keep their ducted system and add ductless units for additional climate control.



More **Efficiency**

Energy-Efficient Lifestyle



Zoning Operation

Multi-zone applications are a more energy-efficient way to heat and cool by customizing comfort for each room. Homeowners can precisely heat and cool only the areas needed and turn off the unit when the area isn't occupied

True Comfort for Every Space


Homeowners can set temperatures and modes individually to customize comfort in multiple spaces. Using different operating conditions or modes based on typical usage of a different rooms like a living room, bedrooms or an office helps save energy and optimize comfort.




More Flexibility

Power up to 6 Zones

One more connection port Is added to the Multi Zone Condensers Of All Capacities



One System, With the Best of Both Worlds



AHU + Ductless

The system can add up to 4 ductless units to the current ducted air handler using the same outdoor unit. This can cover areas that are hard to heat or cool, occupied less often, or part of an addition. The EVOX multi-zone heat pump system is a great solution for more custom heating and cooling needs.



AHU + AHU

No need to change a homeowner's HVAC habits. This large capacity system not only lets users install up to a 3-ton AHU, but also allows users to put two AHUs on one heat pump in a residential multi-zone application.




Ductless

For the most convenient installation and flexible home comfort management, we offer various types of ductless indoor units tailored to meet the unique comfort needs of different rooms.

Wide Variety of Indoor Units for Residential Applications

A comprehensive indoor lineup with 7 types and 33 models with tailored designs for different spaces and functions. This product line has flexibility to combine ductless and ducted indoor units or incorporate an A-Coil to the system.

Ductless Units








Slim Duct 0.75-2 TONS


Air Handling Unit 1.5-3 TONS

Easy Wiring

With SynchroConnect technology, the Midea multi-zone systems can self-diagnose the connection status after the installer connects the wires and line sets, to see whether they're right or wrong.

And what's more amazing is, with proper wiring between indoor units and the condenser, the system can automatically synchronize the refrigerant lines to the wires, even when the lines are connected to the wrong ports, and vice versa. That means when dealing with line sets and wires, Midea installers can focus on correctly connecting the refrigerant lines, or the wires, and the other will automatically match to it with the activation of SynchroConnect technology.







INVERTER HEAT PUMP

1.5-5

Tons Available

REGULAR & EXTREME

Heat Pumps Available

地25

SEER2



Multi-Zone Combination Rule

Advanced heat MULTI INDOOR UNITS COMBINATION RULE

		Avaliable	Standard			0.00	Optional Combi	nation(Only run)	
Multi D	C Outdoor Unit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
				12	6+6	6+6+6			
		Wall mounted:		18	6+9	6+6+9			
		6K/9K/12K/18K;	Non-dusted/		6+12	6+9+9			
		Cassette/Low-static Duct/ Console/Floor Ceiling:	Non-ducted/ Ducted: 6+6+6		6+18				
		6K/9K/12K/18K; High-static duct: 9K/12K			9+9				
	MO3EX-	(should be considered as 18K)		100	9+12	1.01			
1 drive 3	H18B-2A	-			12+12	1.1 1.2			
				12	6+6				
		When there One Way Cassette in the combination:		18	6+9				
		Wall mounted: 6K/9K/12K/18K; Cassette/One Way Cassette/	Non-ducted/		6+12				
		Low-static Duct/Console/ Floor Ceiling:	Ducted: 6+6+6		6+18				
		6K/9K/12K/18K;	01010	-	9+9	-			
		High-static duct: 9K/12K (should be considered as 18K)			9+12			n	
					12+12				
		High-static duct(Only):	Ducted:	9	9+9				
		9K/12K	9+9	12	9+12				
				121	12+12	2) (2		
				18	6+6	6+6+6	6+6+6+6		
				24	6+9	6+6+9	6+6+6+9		
					6+12	6+6+12	6+6+6+12		
					6+18	6+6+18	6+6+9+9		
		Wall mounted:			6+24	6+6+24	6+6+9+12		
		6K/9K/12K/18K/24K; Cassette/Low-static Duct/			9+9	6+9+9	6+9+9+9	·	
		Console/Floor Ceiling: 6K/9K/12K/18K/24K;	Non-ducted/ Ducted:		9+12	6+9+12	6+9+9+12		
		High-static duct:			9+18	6+9+18	9+9+9+9		
		9K/12K (should be considered as 18K);	6+6+6+9		9+24	6+12+12	· ·		
		18K/24K (should be considered as 24K);			12+12	6+12+18			8
		(Silvala de Collinate da 24K),			12+18	9+9+9			
				12+24	9+9+12				
				18+18	9+9+18				
	MO4EX-					9+12+12			
	H27B-2A					12+12+12			
				18	6+6	6+6+6			
				24	6+9	6+6+9			
					6+12	6+6+12			
		When there			6+18	6+6+18		· ·	2
		One Way Cassette in the combination:			6+24	6+6+24		·	
		Wall mounted; 6K/9K/12K/18K/24K;			9+9	6+9+9			
		Cassette/One Way Cassette/			9+12	6+9+12			
		Console/Floor Ceiling:	/		9+18	6+9+18		·	· -
		6K/9K/12K/18K/24K; High-static duct:			9+24	6+12+12			
		9K/12K (should be considered as 18K);			12+12	6+12+18			
		18K/24K			12+18	9+9+9			
		(should be considered as 24K);			12+24	9+9+12			
					18+18	9+9+18			
						9+12+12			
						12+12+12			
		When there AHU in the combination: Wall mounted: 6K/9K/12K; Cassette/Low-static Duct/Console/	,	18	6+18	6+6+18			
		when there and in the combinations wall included: 6K/9K/12K; Cassettla-Low-static Duct/Console/ Floor Ceiling: 6K/9K/12K; High-static duct: 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K); AHU: 18K/24K	/	24	9+18	6+9+18			
			·		12+18	9+9+18	(C)	·	· · · · · · · · · · · · · · · · · · ·
		When there One Way Cassette and AHU both in the combination: Wall mounted: 6K/9K/12K;	,	18	6+18			<u>.</u>	
		in the combination. Wall mixing leaf by SN 12A; Cassette/Tow SN2 Cassette/Tow-static Duct/ Console/Floor Ceiling: 6K/9K/12K; High-static duct: 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K); AHU: 18K/24K	/	24	9+18				
		18K/24K(should be considered as 24K); AHU: 18K/24K			12+18				
				9	9+9				
				12	9+12				
				18	9+18				
		High-static duct(Only): 9K/12K/18K/24K	Ducted: 9+18	24	9+24				
					12+12			21.0	
					12+18	20 O	100 50		
					12+24				

se de po		Avaliable	Standard				Optional Combin	ation(Only run)	
Multi DC	C Outdoor Unit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
				24	6+18	6+6+6	6+6+6+6	6+6+6+6+6	
				30	6+24	6+6+9	6+6+6+9	6+6+6+6+9	
					9+9	6+6+12	6+6+6+12	6+6+6+6+12	
					9+12	6+6+18	6+6+6+18	6+6+6+6+18	
				V)	9+18	6+6+24	6+6+6+24	6+6+6+9+9	
					9+24	6+9+9	6+6+9+9	6+6+6+9+12	
					12+12	6+9+12	6+6+9+12	6+6+6+9+18	
					12+18	6+9+18	6+6+9+18	6+6+9+9+9	
					12+24	6+9+24	6+6+9+24	6+6+9+9+12	
				-	18+18	6+12+12	6+6+12+12	6+6+9+9+18	
					10+10				
		Wall mounted:				6+12+18	6+6+12+18	6+9+9+9+9	
		6K/9K/12K/18K/24K/30K;				6+12+24	6+6+12+24	6+9+9+9+12	
		Cassette/Low-static Duct/				6+18+18	6+6+18+18	6+9+9+9+18	
		Console/Floor Ceiling:				9+9+9	6+9+9+9	9+9+9+9+9	
		6K/9K/12K/18K/24K;	Non-ducted/			9+9+12	6+9+9+12	9+9+9+9+12	
			Ducted: 6+6+6+9+9			9+9+18	6+9+9+18		
		High-static duct:	0.0.0.3.3			9+9+24	6+9+9+24		
		9K/12K (should be considered as 18K);				9+12+12	6+9+12+12		
		18K/24K				9+12+18	6+9+12+18		
		(should be considered as 24K);				9+12+24	6+12+12+12		
						9+18+18	6+12+12+18		
						12+12+12	9+9+9+9		
						12+12+18	9+9+9+12		
							9+9+9+18	-	
						12+12+24		<u> </u>	
				8 8		12+18+18	9+9+12+12		
						· · · · · ·	9+9+12+18	<u> </u>	
							9+12+12+12	1	
							12+12+12+12		
				24	6+18	6+6+6	6+6+6+6		
				30	6+24	6+6+9	6+6+6+9		
					9+9	6+6+12	6+6+6+12	100	
					9+12	6+6+18	6+6+6+18		
					9+18	6+6+24	6+6+6+24		
					9+24	6+9+9	6+6+9+9	1.5	
					12+12	6+9+12	6+6+9+12		
					12+18	6+9+18	6+6+9+18		
		Marie ale and		_	12+18	6+9+18	6+6+9+24		
		When there							
		One Way Cassette in the combination:		-	18+18	6+12+12	6+6+12+12		
		Wall mounted:				6+12+18	6+6+12+18		
		6K/9K/12K/18K/24K/30K;				6+12+24	6+6+12+24		
1111		6				6+18+18	6+6+18+18	<u> </u>	
Irive 5	MO5EX-	Cassette/One Way Cassette/ Low-static Duct/		27	2 0	9+9+9	6+9+9+9		
H36B-2A	Console/Floor Ceiling:	/			9+9+12	6+9+9+12			
	CONSOIC/ 1 IOO1 CO	6K/9K/12K/18K/24K;				9+9+18	6+9+9+18		
						9+9+24	6+9+9+24		
						9+12+12	6+9+12+12	a a	
		(should be considered as 18K);		100		9+12+18	6+9+12+18		
		18K/24K		V. 100	15	9+12+24	6+12+12+12		
		(should be considered as 24K);		100		9+18+18	6+12+12+18		
						12+12+12	9+9+9+9		
				200			9+9+9+12	A	
						12+12+18			
				-		12+12+24	9+9+9+18		
						12+18+18	9+9+12+12		
							9+9+12+18		
							9+12+12+12		
							12+12+12+12		
		When there		24	6+18	6+6+18	6+6+6+18	6+6+6+6+18	
		AHU in the combination:		30	6+24	6+6+24	6+6+6+24	6+6+6+9+18	
		Wall mounted: 6K/9K/12K/18K;			9+18	6+9+18	6+6+9+18	6+6+9+9+18	
		Cassette/Low-static Duct/			9+24	6+9+24	6+6+9+24	6+9+9+9+18	
		Cassette/Low-static Duct/ Console/Floor Ceiling:			12+18	6+12+18	6+6+12+18		
		6K/9K/12K/18K;			12+24	6+12+24	6+6+12+24		
		100500000000000000000000000000000000000	/		18+18	9+9+18	6+9+9+18		
		High-static duct: 9K/12K			13.10	9+9+24	6+9+9+24	-	
		(should be considered as 18K);				9+12+18		·	
		18K/24K					6+9+12+18		
		(should be considered as 24K);				9+12+24	6+12+12+18		
		AULI 101/041/701/				12+12+18	9+9+9+18		
		AHU: 18K/24K/30K				12+12+24	9+9+12+18		
		When there		24	6+18	6+6+18	6+6+6+18		
		One Way Cassette and AHU		30	6+24	6+6+24	6+6+6+24		
		both in the combination: Wall mounted: 6K/9K/12K/18K;			9+18	6+9+18	6+6+9+18		
		Tall mounted, on on lary lon,			9+24	6+9+24	6+6+9+24		
		Cassette/One Way Cassette/			12+18	6+12+18	6+6+12+18		
		Low-static Duct/			12+24	6+12+24	6+6+12+24		
		Console/Floor Ceiling: 6K/9K/12K/18K;	/		18+18	9+9+18	6+9+9+18		
		ON SIN IZIN ION;				9+9+24	6+9+9+24		
		High-static duct:				9+12+18	6+9+12+18		
		9K/12K(should be considered as 18K);				9+12+24	6+12+12+18		
		18K/24K(should be considered as 24K);				12+12+18			
		AHU: 18K/24K/30K					9+9+9+18		
		A110, 101/241/301		10	6.0	12+12+24	9+9+12+18		
				18	9+9	9+9+9			
				24	9+12	9+9+12			
					9+18	9+9+18			
					9+24	9+9+24			
				7.0	3.24	3.3.24			
		High-static duct(Only):	Ducted:		12+12	9+12+12			
		High-static duct(Only): 9K/12K/18K/24K	Ducted: 12+12+12		12+12	9+12+12			
					12+12 12+18	9+12+12 9+12+18			
					12+12	9+12+12 9+12+18 9+12+24			
					12+12 12+18	9+12+12 9+12+18			

Advanced heat MULTI INDOOR UNITS COMBINATION RULE

		Avaliable	Standard				Optional Combin	nation(Only run)	
Multi D	C Outdoor Unit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
				30	6+24	6+6+18	6+6+6+6	6+6+6+6+6	6+6+6+6+6
				36	6+30	6+6+24	6+6+6+9	6+6+6+6+9	6+6+6+6+6+9
					6+36	6+6+30	6+6+6+12	6+6+6+6+12	6+6+6+6+6+12
					9+18	6+6+36	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
					9+24	6+9+12		6+6+6+6+24	6+6+6+6+9+9
					9+24	6+9+12	6+6+6+24	6+6+6+9+9	6+6+6+6+9+9
				- 10	9+36	6+9+24	6+6+9+12	6+6+6+9+12	6+6+6+6+9+18
					12+12	6+9+30	6+6+9+18	6+6+6+9+18	6+6+6+6+12+12
					12+18	6+9+36	6+6+9+24	6+6+6+9+24	6+6+6+6+12+18
					12+24	6+12+18	6+6+12+12	6+6+6+12+12	6+6+6+9+9+9
					12+30	6+12+24	6+6+12+18	6+6+6+12+18	6+6+6+9+9+12
					12+36	6+12+30	6+6+12+24	6+6+6+12+24	6+6+6+9+9+18
				50 100	18+18	6+12+36	6+6+18+18	6+6+6+18+18	6+6+6+9+12+12
					18+24	6+18+18	6+6+18+24	6+6+6+18+24	6+6+6+9+12+18
					18+30	6+18+24	6+9+9+9	6+6+9+9+9	6+6+6+12+12+12
					18+36	6+18+30	6+9+9+12	6+6+9+9+12	6+6+6+12+12+18
					24+24	6+18+36	6+9+9+18	6+6+9+9+18	6+6+9+9+9+9
					24+30	9+9+9	6+9+9+24	6+6+9+9+24	6+6+9+9+9+12
					24+36	9+9+12	6+9+12+12	6+6+9+12+12	6+6+9+9+9+18
					30+30	9+9+18	6+9+12+18	6+6+9+12+18	6+6+9+9+12+12
						9+9+24	6+9+12+24	6+6+9+12+24	6+6+9+9+12+18
						9+9+30	6+9+18+18	6+6+9+18+18	6+6+9+12+12+12
						9+9+36	6+9+18+24	6+6+9+18+24	6+6+9+12+12+18
								6+6+12+12+12	
				-		9+12+12	6+12+12+12 6+12+12+18	6+6+12+12+12	6+9+9+9+9+9
									6+9+9+9+9+18
						9+12+24	6+12+12+24	6+6+12+12+24	
		Wall mounted:				9+12+30	6+12+18+18	6+6+12+18+18	6+9+9+9+12+12
		6K/9K/12K/18K/24K/30K/36K;				9+12+36	6+12+18+24	6+9+9+9+9	6+9+9+9+12+18
		Cassette/Low-static Duct/				9+18+18	9+9+9+9	6+9+9+9+12	6+9+9+12+12+12
		Cassette/Low-static Duct/ Console/Floor Ceiling:	Ducted:			9+18+24	9+9+9+12	6+9+9+9+18	9+9+9+9+9
		6K/9K/12K/18K/24K;	9+9+9+9			9+18+30	9+9+9+18	6+9+9+9+24	9+9+9+9+9+12
			Non-ducted:			9+18+36	9+9+9+24	6+9+9+12+12	9+9+9+9+9+18
		High-static duct: 9K/12K	9+9+9+9+12			12+12+12	9+9+12+12	6+9+9+12+18	9+9+9+9+12+12
		(should be considered as 18K);				12+12+18	9+9+12+18	6+9+9+12+24	9+9+9+12+12+12
		18K/24K				12+12+24	9+9+12+24	6+9+9+18+18	
		(should be considered as 24K);				12+12+30	9+9+18+18	6+9+12+12+12	
						12+12+36	9+9+18+24	6+9+12+12+18	
						12+18+18	9+12+12+12	6+9+12+12+24	
						12+18+24	9+12+12+18	6+9+12+18+18	
						12+18+30	9+12+12+24	6+12+12+12+12	
						18+18+18	9+12+18+18	6+12+12+12+18	
1 drive 6				-		6+24+24	9+12+18+24	9+9+9+9+9	
	MO6EX-					9+24+24	9+18+18+18	9+9+9+9+12	
	H48B-2A								
						12+24+24	12+12+12+12	9+9+9+9+18	
						18+18+24	12+12+12+18	9+9+9+9+24	
							12+12+12+24	9+9+9+12+12	
							12+12+18+18	9+9+9+12+18	
							6+6+6+30	9+9+9+12+24	
							6+6+6+36	9+9+9+18+18	
							6+6+9+30	9+9+12+12+12	
							6+6+9+36	9+9+12+12+18	
							6+6+12+30	9+12+12+12+12	
							6+6+12+36	9+12+12+12+18	
							6+6+18+30	12+12+12+12+12	
							6+6+24+24	6+6+6+6+30	
							6+9+9+30	6+6+6+6+36	
							6+9+9+36	6+6+6+9+30	
							6+9+12+30	6+6+6+9+36	
							6+9+12+36	6+6+6+12+30	
							6+9+12+36	6+6+9+9+30	
							6+9+24+24	6+6+9+12+30	
							6+18+18+18	6+9+9+9+30	
							9+9+9+30		
							9+9+9+36		
					0.01	0.0.0	9+9+12+30	0.0.0.0.	
				30	6+24	6+6+18	6+6+6+6	6+6+6+6+6	
				36	6+30	6+6+24	6+6+6+9	6+6+6+6+9	
					6+36	6+6+30	6+6+6+12	6+6+6+6+12	
					9+18	6+6+36	6+6+6+18	6+6+6+6+18	
					9+24	6+9+12	6+6+6+24	6+6+6+6+24	
					9+30	6+9+18	6+6+9+9	6+6+6+9+9	
		When there			9+36	6+9+24	6+6+9+12	6+6+6+9+12	
		One Way Cassette			12+12	6+9+30	6+6+9+18	6+6+6+9+18	
		in the combination:			12+18	6+9+36	6+6+9+24	6+6+6+9+24	
		Wall mounted:			12+24	6+12+18	6+6+12+12	6+6+6+12+12	
		6K/9K/12K/18K/24K/30K/36K; Cassette/One Way Cassette/			12+30	6+12+24	6+6+12+18	6+6+6+12+18	
		Low-static Duct/Console/			12+36	6+12+30	6+6+12+24	6+6+6+12+24	
		Floor Ceiling:	/		18+18	6+12+36	6+6+18+18	6+6+6+18+18	
		6K/9K/12K/18K/24K;			18+24	6+18+18	6+6+18+24	6+6+6+18+24	
		High-static duct:			18+30	6+18+24	6+9+9+9	6+6+9+9+9	
		9K/12K			18+36	6+18+30	6+9+9+12	6+6+9+9+12	
		(should be considered as 18K);		_	24+24	6+18+36	6+9+9+18	6+6+9+9+18	
		18K/24K			24+24	9+9+9	6+9+9+18	6+6+9+9+24	
		(should be considered as 24K);							
		(0.100.00.00.00.00.00.00.00.00)			24+36	9+9+12	6+9+12+12	6+6+9+12+12	
		(0.0.00	6.6.46.4	0.0.0.0.0	
		(9+9+18	6+9+12+18	6+6+9+12+18	
		(4.04.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.4.		\equiv		9+9+24	6+9+12+24	6+6+9+12+24	
		(\equiv		9+9+24 9+9+30	6+9+12+24 6+9+18+18	6+6+9+12+24 6+6+9+18+18	
		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		\equiv		9+9+24	6+9+12+24	6+6+9+12+24	

		Avaliable	Standard				Optional Combin	nation(Only run)	
Multi E	DC Outdoor Unit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
						9+12+18	6+12+12+18	6+6+12+12+18	
						9+12+24	6+12+12+24	6+6+12+12+24	
						9+12+30	6+12+18+18	6+6+12+18+18	
				_		9+12+36	6+12+18+24	6+9+9+9+9	
						9+18+18	9+9+9+9	6+9+9+9+12	
						9+18+24	9+9+9+12	6+9+9+9+18	
						9+18+30	9+9+9+18	6+9+9+9+24	
						9+18+36	9+9+9+24	6+9+9+12+12	
					0 10	12+12+12	9+9+12+12	6+9+9+12+18	
		14/h 11				12+12+18	9+9+12+18	6+9+9+12+24	
		When there One Way Cassette				12+12+24	9+9+12+24	6+9+9+18+18	
		in the combination:				12+12+30	9+9+18+18	6+9+12+12+12	
		Wall mounted: 6K/9K/12K/18K/24K/30K/36K;				12+12+36	9+9+18+24	6+9+12+12+18	
		Cassette/One Way Cassette/				12+18+18	9+12+12+12	6+9+12+12+24	
		Low-static Duct/Console/	9			12+18+24	9+12+12+18	6+9+12+18+18	
		Floor Ceiling: 6K/9K/12K/18K/24K;	/			12+18+30	9+12+12+24	6+12+12+12+12	
						18+18+18	9+12+18+18	6+12+12+12+18	
		High-static duct: 9K/12K					9+12+18+24	9+9+9+9+9	
		(should be considered as 18K);					9+18+18+18	9+9+9+9+12	
		18K/24K					12+12+12+12	9+9+9+9+18	
		(should be considered as 24K);					12+12+12+18	9+9+9+12+12	
							12+12+18+18	9+9+9+12+18	
							12+12+10+10	9+9+9+12+24	
								9+9+9+12+24	
								9+9+12+12+12	
								9+9+12+12+18	
								9+12+12+12	
								9+12+12+12+18	
								12+12+12+12	
				30	6+18	6+6+18	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
				36	6+24	6+6+24	6+6+6+24	6+6+6+6+24	6+6+6+6+9+18
					6+30	6+6+30	6+6+9+18	6+6+6+9+18	6+6+6+9+9+18
					6+36	6+6+36	6+6+9+24	6+6+6+9+24	6+6+9+9+9+18
					9+18	6+9+18	6+6+12+18	6+6+6+12+18	6+9+9+9+9+18
		When there AHU			9+24	6+9+24	6+6+12+24	6+6+6+12+24	9+9+9+9+918
		in the combination:			9+30	6+9+30	6+9+9+18	6+9+9+9+18	
		Wall mounted:			9+36	6+9+36	6+9+9+24	6+9+9+9+24	
		6K/9K/12K/18K/24K/30K/36K;			12+18	6+12+18	6+9+12+18	6+9+9+12+18	
		Cassette/Low-static Duct/			12+24	6+12+24	6+9+12+24	6+9+9+12+24	
1000000000	Irive 6	Console/Floor Ceiling:	,	0	12+30	6+12+30	6+12+12+18	6+9+12+12+18	
I drive 6	MO6EX-	6K/9K/12K/18K/24K;	/		12+36	6+12+36	6+12+12+24	6+9+12+12+24	
	H48B-2A	High-static duct:			18+18	9+9+18	9+9+9+18	6+12+12+12+18	
		9K/12K (should be considered as 18K);			18+24	9+9+24	9+9+9+24	9+9+9+9+18	
		18K/24K			18+30	9+9+30	9+9+12+18	9+9+9+9+24	
		(should be considered as 24K);			18+36	9+9+36	9+9+12+24	9+9+9+12+24	
		AHU: 18K/24K/30K/36K			24+24	9+12+18	9+12+12+18	9+9+9+12+18	
				_	24+30	9+12+24	9+12+12+24	9+9+12+12+18	
					24+36	9+12+30	12+12+12+18	9+12+12+12+18	
					_	12+12+18	12+12+12+24		
						12+12+24		-	
				-		12+12+30			
				30	6+18	6+6+18	6+6+6+18	6+6+6+6+18	
				36	6+24	6+6+24	6+6+6+24	6+6+6+6+24	
					6+30	6+6+30	6+6+9+18	6+6+6+9+18	
					6+36	6+6+36	6+6+9+24	6+6+6+9+24	
		When there			9+18	6+9+18	6+6+12+18	6+6+6+12+18	
		One Way Cassette			9+24	6+9+24	6+6+12+24	6+6+6+12+24	
		and AHU both			9+30	6+9+30	6+9+9+18	6+9+9+9+18	
		in the combination: Wall mounted:			9+36	6+9+36	6+9+9+24	6+9+9+9+24	
		6K/9K/12K/18K/24K/30K/36K;			12+18	6+12+18	6+9+12+18	6+9+9+12+18	
		Cassette/One Way Cassette/			12+24	6+12+24	6+9+12+24	6+9+9+12+24	
		Low-static Duct/			12+30	6+12+30	6+12+12+18	6+9+12+12+18	
		Console/Floor Ceiling:	/		12+36	6+12+36	6+12+12+24	6+9+12+12+24	
		6K/9K/12K/18K/24K;			18+18	9+9+18	9+9+9+18	6+12+12+12+18	
		High-static duct:			18+24	9+9+24	9+9+9+24	9+9+9+9+18	
		9K/12K			18+30	9+9+30	9+9+12+18	9+9+9+9+24	
		(should be considered as 18K); 18K/24K			18+36	9+9+36	9+9+12+24	9+9+9+12+24	
		(should be considered as 24K);		-	24+24	9+12+18	9+12+12+18	9+9+9+12+18	
		AHU: 18K/24K/30K/36K		-	24+30	9+12+24	9+12+12+24	9+9+12+12+18	
		1017 2417 3017 301			24+36	9+12+30	12+12+12+18	9+12+12+12+18	
						9+12+36 12+12+18	12+12+12+24		
						12+12+18			
						12+12+24		V 2	
				18	9+9	9+9+9	9+9+9+9		
				24	9+12	9+9+9	9+9+9+12		
					9+18	9+9+18	9+9+9+18		-
					9+24	9+9+24	9+9+9+24		
					12+12	9+12+12	9+9+12+12	20	
					12+18	9+12+18	9+9+12+18	().	
		High-static duct(Only):	Ducted:		12+24	9+12+24	9+9+12+24		
		9K/12K/18K/24K	12+12+12+12		18+18	12+12+12	9+12+12+12		
					18+24	12+12+18	9+12+12+18		
					24+24	12+12+24	9+12+12+24	-	
							12+12+12+12		
				-			12+12+12+18		
							12+12+12+24		

Advanced heat MULTI INDOOR UNITS COMBINATION RULE

Multi DC Outdoor Unit	Avaliable	Standard	Optional Combination(Only run)					Circumita.	
	Indoor	Combination		Two unit	Three units	Four units	Five units	Six units	
			30	6+24	6+6+18	6+6+6+6	6+6+6+6+6	6+6+6+6+6	
			36	6+30	6+6+24	6+6+6+9	6+6+6+6+9	6+6+6+6+6	
				6+36	6+6+30	6+6+6+12	6+6+6+6+12	6+6+6+6+6+	
				9+18 9+24	6+6+36	6+6+6+18	6+6+6+6+18 6+6+6+6+24	6+6+6+6+6+	
			_	9+30	6+9+12	6+6+9+9	6+6+6+9+9	6+6+6+6+9	
				9+36	6+9+18	6+6+9+12	6+6+6+9+12	6+6+6+6+9	
				12+12	6+9+24	6+6+9+18	6+6+6+9+18	6+6+6+6+9+	
				12+18	6+9+30	6+6+9+24	6+6+6+9+24	6+6+6+6+9+	
				12+24	6+9+36	6+6+12+12	6+6+6+12+12	6+6+6+6+12	
				12+30	6+12+12	6+6+12+18	6+6+6+12+18	6+6+6+6+12	
				12+36	6+12+18	6+6+12+24	6+6+6+12+24	6+6+6+6+12-	
				18+18	6+12+24	6+6+18+18	6+6+6+18+18 6+6+6+18+24	6+6+6+9+9	
				18+24	6+12+30 6+12+36	6+6+18+24	6+6+9+9+9	6+6+6+9+9	
				18+36	6+18+18	6+9+9+12	6+6+9+9+12	6+6+6+9+9+	
				24+24	6+18+24	6+9+9+18	6+6+9+9+18	6+6+6+9+12	
				24+30	6+18+30	6+9+9+24	6+6+9+9+24	6+6+6+9+12	
				24+36	6+18+36	6+9+12+12	6+6+9+12+12	6+6+6+9+12	
				30+30	9+9+9	6+9+12+18	6+6+9+12+18	6+6+6+12+12	
					9+9+12	6+9+12+24	6+6+9+12+24	6+6+6+12+12	
					9+9+18	6+9+18+18	6+6+9+18+18	6+6+6+12+12	
					9+9+24	6+9+18+24 6+12+12+12	6+6+9+18+24 6+6+12+12+12	6+6+9+9+9	
					9+9+36	6+12+12+18	6+6+12+12+18	6+6+9+9+9	
					9+12+12	6+12+12+24	6+6+12+12+24	6+6+9+9+9+	
					9+12+18	6+12+18+18	6+6+12+18+18	6+6+9+9+12	
					9+12+24	6+12+18+24	6+6+12+18+24	6+6+9+9+12	
			100		9+12+30	6+18+18+18	6+6+18+18+18	6+6+9+9+12	
					9+12+36	6+18+18+24	6+6+18+18+24	6+6+9+12+12	
					9+18+18	9+9+9+9	6+9+9+9+9	6+6+9+12+12	
					9+18+24	9+9+9+12 9+9+9+18	6+9+9+9+12 6+9+9+9+18	6+6+9+12+12	
	Wall mounted:				9+18+36	9+9+9+24	6+9+9+9+24	6+6+12+12+12	
	6K/9K/12K/18K/24K/30K/36K;				12+12+12	9+9+12+12	6+9+9+12+12	6+6+12+12+12	
	Cassette/Low-static Duct/				12+12+18	9+9+12+18	6+9+9+12+18	6+9+9+9+9	
	Console/Floor Ceiling:	Non-ducted/			12+12+24	9+9+12+24	6+9+9+12+24	6+9+9+9+9	
	6K/9K/12K/18K/24K;	Ducted:			12+12+30	9+9+18+18	6+9+9+18+18	6+9+9+9+9	
	High shotic door	9+9+9+9+24			12+12+36	9+9+18+24	6+9+9+18+24	6+9+9+9+9	
	High-static duct: 9K/12K		_		12+18+18	9+12+12+12	6+9+12+12+12	6+9+9+9+12	
	(should be considered as 18K);				12+18+24	9+12+12+18	6+9+12+12+18	6+9+9+9+12	
	18K/24K				12+18+30	9+12+12+24 9+12+18+18	6+9+12+12+24 6+9+12+18+18	6+9+9+9+12+12	
	(should be considered as 24K);				18+18+18	9+12+18+24	6+9+12+18+24	6+9+9+12+12	
			-		18+18+24	9+18+18+18	6+9+18+18+18	6+9+9+12+12	
					9+24+24	12+12+12+12	6+12+12+12+12	6+9+12+12+12	
					12+24+24	12+12+12+18	6+12+12+12+18	6+9+12+12+12	
			1		<u> </u>	12+12+12+24	6+12+12+12+24	6+12+12+12+1	
						12+12+18+18	6+12+12+18+18	6+12+12+12+1	
2020 00000						12+12+18+24	6+12+18+18+18	9+9+9+9+9	
MO6EX-			-			12+18+18+18 6+6+6+30	9+9+9+9+9	9+9+9+9+9	
H60B-2A						6+6+6+36	9+9+9+9+18	9+9+9+9+9	
ive C						6+6+9+30	9+9+9+9+24	9+9+9+9+12	
rive 6						6+6+9+36	9+9+9+12+12	9+9+9+9+12	
						6+6+12+30	9+9+9+12+18	9+9+9+9+12-	
						6+6+12+36	9+9+9+12+24	9+9+9+12+12	
						6+6+18+30	9+9+9+18+18	9+9+9+12+12	
						6+6+24+24	9+9+9+18+24 9+9+12+12+12	9+9+12+12+12	
						6+9+9+36	9+9+12+12+18	9+12+12+12+1	
						6+9+12+30	9+9+12+12+24	12+12+12+12+1	
					-		9+9+12+18+18		
							9+9+12+18+24		
							9+9+18+18+18		
							9+12+12+12+12		
					T	<u> </u>	9+12+12+12+18		
							9+12+12+12+24		
							9+12+12+18+18		
							12+12+12+12+12		
							12+12+12+12+24		
							12+12+12+18+18		
	-		30	6+24	6+6+18	6+6+6+6	6+6+6+6+6		
			36	6+30	6+6+24	6+6+6+9	6+6+6+6+9		
				6+36	6+6+30	6+6+6+12	6+6+6+6+12		
			-	9+18 9+24	6+6+36	6+6+6+18 6+6+6+24	6+6+6+6+18 6+6+6+6+24		
				9+24	6+9+9	6+6+9+9	6+6+6+9+9		
				9+36	6+9+18	6+6+9+12	6+6+6+9+12		
				12+12	6+9+24	6+6+9+18	6+6+6+9+18		
				12+18	6+9+30	6+6+9+24	6+6+6+9+24		
	When there			12+24	6+9+36	6+6+12+12	6+6+6+12+12		
	One Way Cassette in the combination:			12+30	6+12+12	6+6+12+18	6+6+6+12+18		
	Wall mounted:			12+36	6+12+18	6+6+12+24	6+6+6+12+24		
	6K/9K/12K/18K/24K/30K/36K;			18+18	6+12+24	6+6+18+18	6+6+6+18+18		
	C			18+24	6+12+30 6+12+36	6+6+18+24	6+6+6+18+24 6+6+9+9+9		
	Cassette/One Way Cassette/	. /		18+36	6+18+18	6+9+9+12	6+6+9+9+12		
	Low-static Duct/Console/Floor Ceiling 6K/9K/12K/18K/24K;	. /		24+24	6+18+24	6+9+9+18	6+6+9+9+18		
	519 519 1219 1019 2411,			24+30	6+18+30	6+9+9+24	6+6+9+9+24		
	High-static duct:			24+36	6+18+36	6+9+12+12	6+6+9+12+12		
	9K/12K				9+9+9	6+9+12+18	6+6+9+12+18		
	(should be considered as 18K);				9+9+12	6+9+12+24	6+6+9+12+24		
	18K/24K (should be considered as 24K);				9+9+18	6+9+18+18	6+6+9+18+18		
	(another see considered as 24N);				9+9+24	6+9+18+24	6+6+9+18+24		
					9+9+30 9+9+36	6+12+12+12	6+6+12+12+12		
					9+9+36	6+12+12+18	6+6+12+12+18 6+6+12+12+24		
					9+12+18	6+12+18+18	6+6+12+18+18		
					9+12+24	6+12+18+24	6+6+12+18+24		
					9+12+30	6+18+18+18	6+6+18+18+18		

^{1.} If the total indoor unit load exceeds the nominal capacity of the outdoor unit, the practical output capacity of every indoor unit will be correspondingly attenuated. This situation is very evident during heating mode.

2. If the size of the indoor units is the same, the combinations of small indoor units can be applied to the same size units. (For example, the size of 9K and 12K MSEHU is the same, so the 12K unit can be considered as 9K and applied to the combinations of 9K units.)

3. For a 12K MSESU, it should be considered equivalent to an 18K MSEHU unit in combination charts if they share identical physical dimensions.

4. For AHU series:

a, The AHU fan will stop (follow me On) or run intermittently (follow me Off) when it reaches the set temperature;

b, When connected to a third-party thermostat via 24V, if the AHU has no active heating demand, the thermostat's fan-ON command will be ignored.

c, The system will start operating when the AHU receives an emergency heating demand.

Multi Di	C Outdoor Unit	Avaliable	Standard				Optional Combin	nation(Only run)	
Piditi Di	o outdoor offit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
						9+18+18	9+9+9+9	6+9+9+9+9	
						9+18+24	9+9+9+12	6+9+9+9+12	
						9+18+30	9+9+9+18	6+9+9+9+18	
						9+18+36 12+12+12	9+9+9+24 9+9+12+12	6+9+9+9+24 6+9+9+12+12	
						12+12+18	9+9+12+18	6+9+9+12+18	
						12+12+24	9+9+12+24	6+9+9+12+24	
						12+12+30	9+9+18+18	6+9+9+18+18	
						12+12+36	9+9+18+24	6+9+9+18+24	
				_		12+18+18	9+12+12+12	6+9+12+12+12 6+9+12+12+18	
						12+18+24	9+12+12+24	6+9+12+12+24	
						12+18+36	9+12+18+18	6+9+12+18+18	
						18+18+18	9+12+18+24	6+9+12+18+24	
		When there				18+18+24	9+18+18+18	6+9+18+18+18	
		One Way Cassette					12+12+12+12	6+12+12+12+12	
		in the combination: Wall mounted:					12+12+12+18	6+12+12+12+18 6+12+12+12+24	
		6K/9K/12K/18K/24K/30K/36K;					12+12+18+18	6+12+12+18+18	
							12+12+18+24	6+12+18+18+18	
		Cassette/One Way Cassette/					12+18+18+18	9+9+9+9+9	
		Low-static Duct/Console/Floor Ceiling	g: /					9+9+9+9+12	
		6K/9K/12K/18K/24K;						9+9+9+9+18	
		High-static duct:						9+9+9+9+24 9+9+9+12+12	
		9K/12K						9+9+9+12+18	
		(should be considered as 18K);						9+9+9+12+24	
		18K/24K (should be considered as 24K);						9+9+9+18+18	
		Contain and the leading and and and the state of the stat						9+9+9+18+24	
								9+9+12+12+12	
								9+9+12+12+18	
								9+9+12+12+24	
								9+9+12+18+24	
								9+9+18+18+18	
								9+12+12+12+12	
								9+12+12+12+18	
								9+12+12+12+24	
								9+12+12+18+18 12+12+12+12+12	
								12+12+12+12+18	
								12+12+12+12+24	
								12+12+12+18+18	
				30	6+18	6+6+18	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
				36	6+24	6+6+24	6+6+6+24	6+6+6+6+24	6+6+6+6+9+18
				_	6+30 6+36	6+6+30 6+6+36	6+6+9+18 6+6+9+24	6+6+6+12+18 6+6+6+12+24	6+6+6+9+9+18 6+9+9+9+9+18
		When there			9+18	6+9+18	6+6+12+18	6+9+9+9+18	9+9+9+9+9+18
		AHU in the combination:			9+24	6+9+24	6+6+12+24	6+9+9+9+24	
1 drive C	ive 6	Wall mounted; 6K/9K/12K/18K/24K/30K/36K;			9+30	6+9+30	6+9+9+18	6+9+9+12+18	
1 drive 6	MO6EX-	317 317 1217 1017 2417 3017 30K;			9+36	6+9+36	6+9+9+24	6+9+9+12+24	
	H60B-2A	Cassette/Low-static Duct/		-	12+18	6+12+18	6+9+12+18	6+9+12+12+18	
		Console/Floor Ceiling:			12+24 12+30	6+12+24 6+12+30	6+9+12+24 6+12+12+18	6+9+12+12+24 6+12+12+12+18	
		6K/9K/12K/18K/24K;	/		12+36	6+12+36	6+12+12+24	9+9+9+9+18	
		High-static duct:			18+18	9+9+18	9+9+9+18	9+9+9+9+24	
		9K/12K			18+24	9+9+24	9+9+9+24	9+9+9+12+24	
		(should be considered as 18K); 18K/24K		8	18+30	9+9+30	9+9+12+18	9+9+9+12+18	
		(should be considered as 24K);			18+36 24+24	9+9+36 9+12+18	9+9+12+24 9+12+12+18	9+9+12+12+18 9+12+12+12+18	
		AHU;			24+30	9+12+24	9+12+12+24	9+12+12+12+10	
		18K/24K/30K/36K			24+36	9+12+30	12+12+12+18		
						9+12+36	12+12+12+24		
						12+12+18			
						12+12+24			
				30	6+18	12+12+30 6+6+18	6+6+6+18	6+6+6+6+18	
				36	6+24	6+6+24	6+6+6+24	6+6+6+6+24	
					6+30	6+6+30	6+6+9+18	6+6+6+12+18	
		When there			6+36	6+6+36	6+6+9+24	6+6+6+12+24	
		One Way Cassette and AHU			9+18	6+9+18	6+6+12+18	6+9+9+9+18	
		both in the combination: Wall mounted(AG/EP/AB):		-	9+24	6+9+24 6+9+30	6+6+12+24 6+9+9+18	6+9+9+9+24 6+9+9+12+18	
		6K/9K/12K/18K/24K/30K/36K;			9+36	6+9+36	6+9+9+18	6+9+9+12+18	
					12+18	6+12+18	6+9+12+18	6+9+12+12+18	
		Cassette/One Way Cassette/			12+24	6+12+24	6+9+12+24	6+9+12+12+24	
		Low-static Duct/Console/ Floor Ceiling: 6K/9K/12K/18K/24K;			12+30	6+12+30	6+12+12+18	6+12+12+12+18	
		coming. ory ary lary lory 24K;	,		12+36	6+12+36	6+12+12+24	9+9+9+9+18	
		High-static duct:	/	_	18+18 18+24	9+9+18 9+9+24	9+9+9+18	9+9+9+9+24	
		9K/12K			18+24	9+9+24	9+9+9+24	9+9+9+12+24	
		(should be considered as 18K); 18K/24K			18+36	9+9+36	9+9+12+24	9+9+12+12+18	
		(should be considered as 24K);			24+24	9+12+18	9+12+12+18	9+12+12+12+18	
					24+30	9+12+24	9+12+12+24		
		AHU:			24+36	9+12+30	12+12+12+18		
		18K/24K/30K/36K				9+12+36	12+12+12+24		
						12+12+18			
						12+12+30			
				18	9+9	9+9+9	9+9+9+9	9+9+9+9+9	
				24	9+12	9+9+12	9+9+9+12	9+9+9+9+12	
					9+18	9+9+18	9+9+9+18	9+9+9+12+12	
					9+24	9+9+24	9+9+9+24	9+9+12+12+12	
		10.00 10.00 10 10.000			12+12	9+12+12 9+12+18	9+9+12+12	9+12+12+12+12	
		High-static duct(Only):	Ducted:	8	12+24	9+12+24	9+9+12+24	Z-12-12-12-12	
		9K/12K/18K/24K	9+12+12+12+12		18+18	12+12+12	9+12+12+12		
					10.01				
					18+24	12+12+18	9+12+12+18		
					24+24	12+12+18	9+12+12+24		

Etreme Heat MULTI INDOOR UNITS COMBINATION RULE

		Avaliable	Standard	Optional Combination(Only run)					
Multi [OC Outdoor Unit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
				18	6+6	6+6+6			
				24	6+9	6+6+9			
				-	6+12	6+6+12			
					6+18	6+6+18			
		Wall mounted:			6+24	6+6+24			
		6K/9K/12K/18K/24K;			9+9	6+9+9			
		Cassette/One Way Cassette/ Low-static Duct/Console/			9+12	6+9+12		- 100	
		Floor Ceiling: 6K/9K/12K/18K/24K;	Non-ducted/ Ducted:		9+18	6+9+18			
		High-static duct:	6+6+6		9+24	6+12+12			
		9K/12K			12+12	6+12+18			
		(should be considered as 18K); 18K/24K		-	12+18	9+9+9			
		(should be considered as 24K);		S. 7	12+24	9+9+12			
					18+18	9+9+18			
						9+12+12			
						12+12+12			
				18	6+6				
				24	6+9	0		100	
		When there			6+12				
lyper MO3HX-	One Way Cassette in the combination:			6+18					
	Wall mounted; 6K/9K/12K/18K/24K;			6+24					
	Cassette/One Way Cassette/			9+9					
	HIOB-ZA	Low-static Duct/Console/ Floor Ceiling:	/	1 7 - 18 1	9+12				
		6K/9K/12K/18K/24K;	100		9+18				
		High-static duct;	n-		9+24				
		9K/12K (should be considered as 18K);			12+12				
		18K/24K (should be considered as 24K);			12+18			-	
		(should be considered as 24K),			12+24	_			
					18+18				
		When there AHU in the combination:		18	6+18	6+6+18			
		Wall mounted: 6K/9K/12K; Cassette/Low-static Duct/ Console/Floor Ceiling: 6K/9K/12K; High-static duct: 9K/12K/should be considered as 18K); BK/24K(should be considered as 24K);	/	24	9+18	6+9+18			
		AHU: 18K/24K		-	12+18	9+9+18	-		
		When there One Way Cassette and AHU both in the combination: Wall mounted: 6K/9K/12K:		18	6+18				
		Cassatta/One Way Cassatta/Low static Dust/Consola/	/	24	9+18				
		Floor Ceiling: 6K/9K/12K; High-static duct: 9K/12K(should be considered as 18K); 18K/24K(should be considered as 24K); AHU: 18K/24K			12+18				
	AHU: 18K/24K		9	9+9	S				
			12	9+12	10 V	-			
				18	9+18				
		High-static duct(Only):	Ducted: 9+9	24	9+24				
		9K/12K/18K/24K			12+12				
					12+18				
				-	12+24				

		Avaliable	Standard				Optional Combir	nation(Only run)	
Multi I	DC Outdoor Unit	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
				24	6+18	6+6+6	6+6+6+6	14	
				30	6+24	6+6+9	6+6+6+9		
					9+9	6+6+12	6+6+6+12	Ti-	8
					9+12	6+6+18	6+6+6+18	0	N
					9+18	6+6+24 6+9+9	6+6+6+24	7	17
					12+12	6+9+12	6+6+9+12	<u> </u>	
					12+18	6+9+18	6+6+9+18	(<u>)</u>	
					12+24	6+9+24	6+6+9+24		
		Well mounted:			18+18	6+12+12	6+6+12+12		
		Wall mounted: 6K/9K/12K/18K/24K/30K;		10		6+12+18	6+6+12+18		·
		Cassette/Low-static Duct/		-		6+12+24	6+6+12+24		
		Console/Floor Ceiling:				6+18+18	6+6+18+18		
		6K/9K/12K/18K/24K;	Non-ducted/ Ducted:	-		6+18+24 9+9+9	6+9+9+9	-	
		High-static duct;	6+6+6+9	-	-	9+9+9	6+9+9+18	0.	
		9K/12K				9+9+18	6+9+9+24	-	
		(should be considered as 18K); 18K/24K				9+9+24	6+9+12+12		
		(should be considered as 24K);				9+12+12	6+9+12+18		
						9+12+18	6+12+12+12		
						9+12+24	6+12+12+18		
						9+18+18	9+9+9+9	1	8
						12+12+12	9+9+9+12	10.5	-
				17		12+12+18	9+9+9+18		2
						12+12+24	9+9+12+12	-	(1)
						12+18+18	9+9+12+18		
							9+12+12+12		Ú.
		17		24	6+18	6+6+6	12 - 12 - 12 - 12	·-	S
				30	6+24	6+6+9	-		
					9+9	6+6+12			×
					9+12	6+6+18			
					9+18	6+6+24		1	12
				_	9+24	6+9+9			
		When there			12+12	6+9+12		-	
		One Way Cassette		_	12+18	6+9+18		-	0
		in the combination: Wall mounted;		-	12+24	6+9+24 6+12+12		17	
		6K/9K/12K/18K/24K/30K;			10+10	6+12+18			N
		Cassette/One Way Cassette/				6+12+24			
		Low-static Duct/Console/	/			6+18+18		-	
	мо4нх-	Floor Ceiling: 6K/9K/12K/18K/24K;	,		100	6+18+24		50	10
	rive 4 H27B-2A H	0K/9K/12K/10K/24K,				9+9+9			
		High-static duct:				9+9+12			
		9K/12K (should be considered as 18K);				9+9+18		-	
		18K/24K				9+9+24			
		(should be considered as 24K);				9+12+12		-	
						9+12+18 9+12+24	-	0	
				10		9+18+18			
						12+12+12		-	
						12+12+18			
						12+12+24			<u> </u>
						12+18+18		-	
		When there		24	6+18	6+6+18	6+6+6+18	1	0
		AHU in the combination:		30	6+24	6+6+24	6+6+6+24	<u> </u>	19
		Wall mounted: 6K/9K/12K/18K;			9+18	6+9+18 6+9+24	6+6+9+18 6+6+9+24	51 <u>-</u>	N-
		Cassette/Low-static Duct/			12+18	6+12+18	6+9+9+18		
		Console/Floor Ceiling: 6K/9K/12K/18K;	4		12+24	6+12+24	6+9+9+24		
			/	0	18+18	9+9+18	9+9+9+18	A	
		High-static duct: 9K/12K				9+9+24			
		(should be considered as 18K);				9+12+18		7.5	
		18K/24K (should be considered as 24K);				9+12+24		1	
		AHU: 18K/24K/30K		_		12+12+18		0. 1.	
		Miles Ales		24	6+18	12+12+24 6+6+18		-	
		When there One Way Cassette and AHU		30	6+24	6+6+24			9
		both in the combination:			9+18	6+9+18			
		Wall mounted: 6K/9K/12K/18K;			9+24	6+9+24		-	
		Cassette/One Way Cassette/			12+18	6+12+18		19	100
		Low-static Duct/Console/ Floor Ceiling: 6K/9K/12K/18K;	/		12+24	6+12+24		1	8
					18+18	9+9+18			15 <u></u>
		High-static duct: 9K/12K			<u> </u>	9+9+24		<u> </u>	N.
		(should be considered as 18K);		100		9+12+18			(1)
		18K/24K (should be considered as 24K);				9+12+24			
		AHU: 18K/24K/30K				12+12+18	-	-	
				18	9+9	9+9+9		92	v
				24	9+12	9+9+12	-	Maria de la companya	
					9+18	9+9+18			
					9+24	9+9+24			
					12+12	9+12+12		7	
		High-static duct(Only): 9K/12K/18K/24K	Ducted: 9+9+9		12+18	9+12+18			
		31 12N 10N 24K	37373		12+24	9+12+24			
						12+12+12			
						12+12+18			-
				-		12.17.54			

Etreme Heat MULTI INDOOR UNITS COMBINATION RULE

		Averticable	Chandred				Optional Combi	nation(Only run)	
Multi I	DC Outdoor Unit	Avaliable Indoor	Standard Combination	One unit	Two unit	Three units	Four units	Five units	Six units
				30	6+24	6+6+12	6+6+6+6	6+6+6+6	OIX UIIILO
				36	6+30	6+6+18	6+6+6+9	6+6+6+6+9	
				-	9+18	6+6+30	6+6+6+18	6+6+6+6+18	
					9+24	6+6+36	6+6+6+24	6+6+6+9+9	
					9+30	6+9+9	6+6+9+9	6+6+6+9+12	
					9+36	6+9+12	6+6+9+12	6+6+6+9+18	
					12+12	6+9+18	6+6+9+18	6+6+6+12+12	
					12+18	6+9+24	6+6+9+24	6+6+6+12+18	
					12+24	6+9+30	6+6+12+12	6+6+9+9+9	
					12+30	6+12+12	6+6+12+18	6+6+9+9+12	
					12+36	6+12+18	6+6+12+24	6+6+9+9+18	
					18+18	6+12+24	6+6+18+18	6+6+9+12+12	
					18+24	6+12+30	6+6+18+24	6+6+12+12+12	
					18+30	6+18+18	6+9+9+9	6+9+9+9+9	
					24+24	6+18+24	6+9+9+12	6+9+9+9+12	
						9+9+9	6+9+9+18	6+9+9+12+12	
						9+9+12	6+9+9+24	9+9+9+9+9	
						9+9+18	6+9+12+12	9+9+9+9+12	
						9+9+24	6+9+12+18		
						9+9+30	6+9+12+24		
						9+12+12	6+9+18+18		
						9+12+18	6+9+18+24		
						9+12+24	6+12+12+12		
		M-11				9+18+18	6+12+12+18		
		Wall mounted: 6K/9K/12K/18K/24K/30K/36K;				9+18+24	6+12+12+24		
		Cassette/Low-static Duct/				12+12+12	6+12+18+18	·	
		Console/Floor Ceiling: 6K/9K/12K/18K/24K;	Non-ducted/			12+12+18	6+12+18+24		
		High-static duct:	Ducted: 6+6+6+9+9			12+12+24	6+18+18+18		
		9K/12K	010101919			12+18+18	9+9+9+9		
		(should be considered as 18K); 18K/24K				12+18+24	9+9+9+12		
		(should be considered as 24K);				18+18+18	9+9+9+18		
						6+24+24	9+9+9+24	(h <u> </u>	
						9+24+24	9+9+12+12		
						12+24+24	9+9+12+18	· · · · · · · · · · · · · · · · · · ·	
800							9+9+12+24		
Hyper	мо5нх-						9+9+18+18		
1 drive 5	H36B-2A						9+9+18+24		
							9+12+12+12		
						_	9+12+12+16	S S	
							9+12+18+18	-	
							9+18+18+18		
							12+12+12+12		
							12+12+12+18		
							12+12+12+24		
							12+12+18+18		
							6+6+6+30		
							6+6+6+36		
							6+6+9+30		
							6+6+9+36		
							6+6+18+30		
							6+6+24+24		
							6+9+9+30		
							6+9+9+36	7 21	
							6+9+12+30		
							6+9+12+36		
				P		-	6+9+18+30	·	
							6+12+12+30		
				30	6+24	6+6+12	6+6+6+6		
				36	6+30	6+6+18	6+6+6+9	·	
					6+36	6+6+24	6+6+6+12		
					9+18	6+6+30	6+6+6+18		
					9+24	6+6+36	6+6+6+24		
		When there			9+30	6+9+9	6+6+9+9		
		One Way Cassette			9+36	6+9+12	6+6+9+12		
		in the combination: Wall mounted:			12+12	6+9+18	6+6+9+18		
		6K/9K/12K/18K/24K/30K/36K;			12+18	6+9+24	6+6+9+24		
		Cassette/One Way Cassette/			12+24	6+9+30	6+6+12+12	 -	
		Low-static Duct/Console/ Floor Ceiling:	/		12+30	6+12+12	6+6+12+18		
		6K/9K/12K/18K/24K;			12+36	6+12+18	6+6+12+24		
		High-static duct:			18+18	6+12+24	6+6+18+18		
		9K/12K			18+24	6+12+30	6+9+9+9		
		(should be considered as 18K); 18K/24K			24+24	6+18+24	6+9+9+12		
		(should be considered as 24K);			2-4-24	9+9+9	6+9+9+18		
						9+9+12	6+9+9+24		
						9+9+18	6+9+12+12		
						9+9+24	6+9+12+18		
				_		9+9+30	6+9+12+24		

Outdoor Unit	Avaliable Indoor	Standard Combination	One unit	Two unit	Three units 9+12+12	Four units 6+9+18+18	Five units	Six units
					9+12+12	6+9+18+18		
			_					
					9+12+18	6+9+18+24		
					9+12+18	6+12+12+12		
							-	
					9+18+18	6+12+12+18		
								-
					12+12+24	6+18+18+18		
	When there				12+18+18	9+9+9+9		
	one Way Cassette		-	-	12+18+24	9+9+9+12		
	Wall mounted:				18+18+18	9+9+9+18		
	6K/9K/12K/18K/24K/30K/36K;							
	Cassette/One Way Cassette/							
		,	-					
	Floor Ceiling:	/					0	
	6K/9K/12K/18K/24K;							
	High-static duct;					9+9+18+18		
	9K/12K				-	9+9+18+24		
						9+12+12+12		
				7		9+12+12+18		
						9+12+12+24		
							Ot to	
			_					
						12+12+12+18		
						12+12+12+24		
						12+12+18+18		
			30	6+18	6+6+18	6+6+6+18	6+6+6+6+18	
			36	6+24	6+6+24			
			-					
			_				0.0.0.0.10	
	When there							
	AHU in the combination:							
			9	9+30	6+9+30	6+9+9+18	2 10	<u> </u>
	on 91/121/101/241/301/301.			9+36	6+12+18	6+9+9+24		
	Cassette/Low-static Duct/			12+18	6+12+24	6+9+12+18		
				12+24	6+12+30	6+9+12+24		
	0K/ 9K/ 12K/ 10K/ 24K,	/		12+30	9+9+18			
yper MO5HX- ive 5 H36B-2A	High-static duct:	,						
	18K/24K							<u> </u>
	(should be considered as 24K);							
	ALIII-		_					
	18K/24K/30K/36K			24+24	12+12+18	9+9+12+24		
	,,				12+12+24	9+12+12+18		
				N		9+12+12+24	10	
						12+12+12+18		
						12+12+12+24		
			30	6+18	6+6+19			
			36					-
	When there			6+36	6+6+36	6+6+9+24		
	One Way Cassette and AHU			9+18	6+9+18	6+6+12+18		
	both in the combination:			9+24	6+9+24	6+6+12+24		
				9+30	6+9+30	6+9+9+18		
	ON 3N 12N 10N 24N 3UK 30K;							
	Cassette/One Way Cassette/		_					
							· ·	
	6K/9K/12K/18K/24K:	1						
	High-static duct:							7 <u></u>
				18+18	9+9+30	9+9+9+18		
	18K/24K			18+24	9+12+18	9+9+9+24		
	(should be considered as 24K);		25	18+30	9+12+24	9+9+12+18		
	AHU: 18K/24K/30K/36K			24+24	12+12+18	9+9+12+24		
							in to	
			24	9+12	9+9+12	9+9+9+12		
				9+18	9+9+18	9+9+9+18	Se	
			-	9+24	9+9+24	9+9+9+24		
					9+12+12			
	High-static dust/Only)	Ductod						-
	9K/12K/18K/24K	Ducted: 9+9+9+9	-					
				18+18	12+12+12	9+12+12+12	<u> </u>	
				18+24	12+12+18	9+12+12+18		
			24+24	12+12+24	9+12+12+24			
				24+24	12+12+24	9+12+12+24		
				24+24	12+12+24			
		One Way Cassette in the combination: Wall mounted: 6K/9K/12K/18K/24K/30K/36K; Cassette/One Way Cassette/ Low-static Duct/Console/ Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K); 18K/24K (should be considered as 24K); MO5HX-H36B-2A MO5HX-High-static duct: 9K/12K/18K/24K; (should be considered as 18K); 18K/24K (should be considered as 24K); MO5HX-H36B-2A When there One Way Cassette and AHU beto in the combination: Wall mounted: 6K/9K/12K/18K/24K; AHU: 18K/24K/30K/36K When there Cone Way Cassette and AHU both in the combination: Wall mounted: 6K/9K/12K/18K/24K/30K/36K Cassette/One Way Cassette/ Low-static Duct/ Console/Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K); 18K/24K (should be considered as 24K); AHU: 18K/24K/30K/36K	One Way Cassette in the combination: Wall mounted: 6K/9K/JRK/24K/JSK/JSK/36K; Cassette/One Way Cassette/ Low-static Dutc/Console/ Floor Ceilling: 6K/9K/JZK/JBK/24K; High-static dut: 9K/JZK (should be considered as 18K); 18K/24K (should be considered as 24K); MO5HX- High-static dut: 9K/JZK (should be considered as 18K); 18K/24K (should be considered as 24K); AHU: 18K/24K/30K/36K When there One Way Cassette and AHU both in the combination: Wall mounted: 6K/9K/JZK/JRK/JZ4K/JOK/JSK; Cassette/One Way Cassette/ Low-static Dutc/ Console/Floor Ceilling: 6K/9K/JZK/JSK/JZAK; High-static duct: 9K/JZK (should be considered as 18K); 18K/24K (should be considered as 18K); 18K/24K (should be considered as 24K); High-static duct: 9K/JZK (should be considered as 24K); AHU: 18K/24K/30K/36K	One Way Cassette in the combination: Wall mounted: 6K/9K/12K/18K/24K/30K/36K; Cassette/One Way Cassette/ Low-sterior Duet/ Cassette/ Low-sterior Calling: / 6K/9K/12K/18K/24K; Hijh-static duet: 9K/12K (should be considered as 18K); 18K/24K (should be considered as 24K); When there AH In the combination: Wall mounted: 6K/9K/12K/18K/24K (should be considered as 24K); Cassette/Low-stetic Duet/ Console/Floor Celling: 6K/9K/12K/18K/24K/30K/36K; Cassette/Low-stetic Duet/ Console/Floor Celling: 6K/9K/12K/18K/24K (should be considered as 18K); 18K/24K (should be considered as 18K); 18K/24K (should be considered as 24K); AHU: 18K/24K/30K/36K When there One Way Cassette/ Low-stetic Duet/ Console/Floor Celling: / 6K/9K/12K/18K/24K/30K/36K; Cassette/One Way Cassette/ Low-stetic Duet/ Console/Floor Celling: / 6K/9K/12K/18K/24K/30K/36K; Cassette/One Way Cassette/ Low-stetic Duet/ Console/Floor Celling: / 6K/9K/12K/18K/24K; High-static duet: 9K/12K (should be considered as 18K); 18K/24K (chould be considered as 24K); AHU: 18K/24K/30K/36K	One Way Cassette in the combination: Well mounted: (6K/9K/12K/9K/24K/36K) (2K/36K; Cassette/One Way Cassette/ Low-static Duct/Console/Floor Ceiling: (7Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (chould be considered as 18K); 18K/24K (chould be considered as 24K);	When there	When there One Wey Cassette in the combination: If the combination	12-12-12 6-12-18-19

Etreme Heat MULTI INDOOR UNITS COMBINATION RULE

Multi DC Outdoor Unit	Avaliable	Standard					nation(Only run)	
	Indoor	Combination		Two unit	Three units	Four units	Five units	Six units
			30 36	6+24 6+30	6+6+18 6+6+24	6+6+6+6	6+6+6+6 6+6+6+9	6+6+6+6+6+
				6+36	6+6+30	6+6+6+12	6+6+6+6+12	6+6+6+6+6+
				9+18 9+24	6+6+36 6+9+9	6+6+6+18 6+6+6+24	6+6+6+6+18 6+6+6+6+24	6+6+6+6+6+
				9+30	6+9+12	6+6+9+9	6+6+6+9+9	6+6+6+6+9+
				9+36	6+9+18	6+6+9+12	6+6+6+9+12	6+6+6+6+9+
				12+12	6+9+24 6+9+30	6+6+9+18 6+6+9+24	6+6+6+9+18 6+6+6+9+24	6+6+6+6+9+
				12+24	6+9+36	6+6+12+12	6+6+6+12+12	6+6+6+6+12+
				12+30	6+12+12	6+6+12+18	6+6+6+12+18 6+6+6+12+24	6+6+6+6+12+
				12+36 18+18	6+12+18 6+12+24	6+6+12+24	6+6+6+18+18	6+6+6+6+12+
				18+24	6+12+30	6+6+18+24	6+6+6+18+24	6+6+6+9+9+
				18+30 18+36	6+12+36 6+18+18	6+9+9+9	6+6+9+9+9	6+6+6+9+9+
				24+24	6+18+24	6+9+9+18	6+6+9+9+18	6+6+6+9+12
				24+30	6+18+30 6+18+36	6+9+9+24 6+9+12+12	6+6+9+9+24 6+6+9+12+12	6+6+6+9+12+
				24.00	9+9+9	6+9+12+18	6+6+9+12+18	6+6+6+12+12
					9+9+12 9+9+18	6+9+12+24 6+9+18+18	6+6+9+12+24 6+6+9+18+18	6+6+6+12+12
					9+9+24	6+9+18+24	6+6+9+18+24	6+6+9+9+9
					9+9+30	6+12+12+12	6+6+12+12+12	6+6+9+9+9+
					9+9+36 9+12+12	6+12+12+18 6+12+12+24	6+6+12+12+18 6+6+12+12+24	6+6+9+9+9+
					9+12+18	6+12+18+18	6+6+12+18+18	6+6+9+9+12
					9+12+24	6+12+18+24 6+18+18+18	6+6+12+18+24 6+6+18+18+18	6+6+9+9+12+
					9+12+36	6+18+18+24	6+6+18+18+24	6+6+9+12+12
					9+18+18	9+9+9+9 9+9+9+12	6+9+9+9+9	6+6+9+12+12
					9+18+24 9+18+30	9+9+9+12	6+9+9+9+12 6+9+9+9+18	6+6+9+12+12+12 6+6+12+12+12
	Wall mounted:				9+18+36	9+9+9+24	6+9+9+9+24	6+6+12+12+12
	6K/9K/12K/18K/24K/30K/36K;	48K			12+12+12	9+9+12+12 9+9+12+18	6+9+9+12+12 6+9+9+12+18	6+6+12+12+12
	Cassette/Low-static Duct/	Non-ducted/ Ducted:			12+12+24	9+9+12+24	6+9+9+12+24	6+9+9+9+9+
	Console/Floor Ceiling:	9+9+9+9+12			12+12+30 12+12+36	9+9+18+18 9+9+18+24	6+9+9+18+18 6+9+9+18+24	6+9+9+9+9+
	6K/9K/12K/18K/24K;	53K			12+12+36	9+12+12+12	6+9+12+12+12	6+9+9+9+12
	High-static duct:	Non-ducted: 6+6+6+9+24			12+18+24	9+12+12+18	6+9+12+12+18	6+9+9+9+12+
	9K/12K (should be considered as 18K);	53K Ducted:			12+18+30	9+12+12+24 9+12+18+18	6+9+12+12+24 6+9+12+18+18	6+9+9+9+12+12
	18K/24K (should be considered as 24K);	6+6+9+9+24			18+18+18	9+12+18+24	6+9+12+18+24	6+9+9+12+12
	(should be considered as 24K);				18+18+24 9+24+24	9+18+18+18	6+9+18+18+18 6+12+12+12+12	6+9+9+12+12+12
					12+24+24	12+12+12+18	6+12+12+12+18	6+9+12+12+12
						12+12+12+24	6+12+12+12+24	6+12+12+12+12
						12+12+18+18	6+12+12+18+18 6+12+18+18+18	6+12+12+12+12 9+9+9+9+9
мобнх-						12+18+18+18	9+9+9+9+9	9+9+9+9+9+
H48B-2A						6+9+24+24 6+9+12+36	9+9+9+9+12 9+9+9+9+18	9+9+9+9+9+
мобнх-						6+9+18+30	9+9+9+9+24	9+9+9+9+12+
rive 6 H60B-2A						6+6+24+24 6+9+9+30	9+9+9+12+12 9+9+9+12+18	9+9+9+9+12+
						6+9+9+36	9+9+9+12+24	9+9+9+12+12
						6+9+12+30	9+9+9+18+18	9+9+9+12+12
						6+9+12+36 6+9+18+30	9+9+9+18+24 9+9+12+12+12	9+9+12+12+12
						6+9+24+24	9+9+12+12+18	9+12+12+12+12
			-			6+12+12+30 6+12+12+36	9+9+12+12+24 9+9+12+18+18	12+12+12+12+12
						6+6+18+30	9+9+12+18+24	
						6+6+24+24 6+9+9+30	9+9+18+18+18 9+12+12+12+12	
						6+9+9+36	9+12+12+12+18	
						6+9+12+30	9+12+12+12+24 9+12+12+18+18	
						6+9+12+36 6+9+18+30	12+12+12+12+12	
						6+12+12+30	12+12+12+12+18	
						9+9+9+30 9+9+9+36	12+12+12+12+24 12+12+12+18+18	
					\$ 1	9+9+12+30	6+6+6+6+30	
					-		6+6+6+6+36 6+6+6+9+30	-
					Œ .		6+6+6+9+36	
							6+6+6+12+30 6+6+9+9+30	
							6+6+9+12+30	
			30	6+24	6+6+18	6+6+6+6	6+9+9+9+30 6+6+6+6	
			36	6+30	6+6+24	6+6+6+9	6+6+6+6+9	
				6+36	6+6+30	6+6+6+12	6+6+6+6+12	
				9+18 9+24	6+6+36 6+9+9	6+6+6+18 6+6+6+24	6+6+6+6+18 6+6+6+6+24	
				9+30	6+9+12	6+6+9+9	6+6+6+9+9	
	When there			9+36 12+12	6+9+18 6+9+24	6+6+9+12 6+6+9+18	6+6+6+9+12 6+6+6+9+18	-
	One Way Cassette			12+18	6+9+30	6+6+9+24	6+6+6+9+24	
	in the combination: Wall mounted;			12+24 12+30	6+9+36 6+12+12	6+6+12+12 6+6+12+18	6+6+6+12+12 6+6+6+12+18	
	6K/9K/12K/18K/24K/30K/36K;			12+36	6+12+12	6+6+12+24	6+6+6+12+24	
	Cassette/One Way Cassette/			18+18	6+12+24	6+6+18+18	6+6+6+18+18	
	Low-static Duct/Console/	/		18+24 18+30	6+12+30 6+12+36	6+6+18+24	6+6+6+18+24 6+6+9+9+9	
		,		18+36	6+18+18	6+9+9+12	6+6+9+9+12	
	Floor Ceiling:			24+24	6+18+24	6+9+9+18	6+6+9+9+18	
	Floor Ceiling: 6K/9K/12K/18K/24K;				6+10+70	64040434	6+6+0+0+24	
	Floor Ceiling:			24+30 24+36	6+18+30 6+18+36	6+9+9+24 6+9+12+12	6+6+9+9+24 6+6+9+12+12	
	Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K);		\equiv	24+30	6+18+36 9+9+9	6+9+12+12 6+9+12+18	6+6+9+12+12 6+6+9+12+18	
	Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K			24+30	6+18+36 9+9+9 9+9+12	6+9+12+12 6+9+12+18 6+9+12+24	6+6+9+12+12 6+6+9+12+18 6+6+9+12+24	
	Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K); 18K/24K			24+30	6+18+36 9+9+9 9+9+12 9+9+18 9+9+24	6+9+12+12 6+9+12+18 6+9+12+24 6+9+18+18 6+9+18+24	6+6+9+12+12 6+6+9+12+18 6+6+9+12+24 6+6+9+18+18 6+6+9+18+24	
	Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K); 18K/24K			24+30	6+18+36 9+9+9 9+9+12 9+9+18 9+9+24 9+9+30	6+9+12+12 6+9+12+18 6+9+12+24 6+9+18+18 6+9+18+24 6+12+12+12	6+6+9+12+12 6+6+9+12+18 6+6+9+12+24 6+6+9+18+18 6+6+9+18+24 6+6+12+12+12	
	Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K); 18K/24K			24+30	6+18+36 9+9+9 9+9+12 9+9+18 9+9+24	6+9+12+12 6+9+12+18 6+9+12+24 6+9+18+18 6+9+18+24	6+6+9+12+12 6+6+9+12+18 6+6+9+12+24 6+6+9+18+18 6+6+9+18+24	
	Floor Ceiling: 6K/9K/12K/18K/24K; High-static duct: 9K/12K (should be considered as 18K); 18K/24K			24+30	6+18+36 9+9+9 9+9+12 9+9+18 9+9+24 9+9+30 9+9+36	6+9+12+12 6+9+12+18 6+9+12+24 6+9+18+18 6+9+18+24 6+12+12+12 6+12+12+18	6+6+9+12+12 6+6+9+12+18 6+6+9+12+24 6+6+9+18+18 6+6+9+18+24 6+6+12+12+12 6+6+12+12+18	

<sup>9+12+30 6+18+18+18

1.</sup> If the total indoor unit load exceeds the nominal capacity of the outdoor unit, the practical output capacity of every indoor unit will be correspondingly attenuated. This situation is very evident during heating mode.

2. If the size of the indoor units is the same, the combinations of small indoor units can be applied to the same size units. (For example, the size of 9K and 12K MSEHU is the same, so the 12K unit can be considered as 9K and 12K MSEHU is the same, so the 12K unit can be considered as 9K and 12K MSESU, it should be considered equivalent to an 18K MSEHU unit in combination charts if they share identical physical dimensions.

Multi DC Outdoor Unit	Avaliable Indoor	Standard Combination	0	and the same of th			nation(Only run)	
	Indoor	Combination	One unit	Two unit	Three units	Four units	Five units	Six units
			8		9+12+36 9+18+18	6+18+18+24 9+9+9+9	6+6+18+18+24	
					9+18+24	9+9+9+12	6+9+9+9+12	
					9+18+30 9+18+36	9+9+9+18 9+9+9+24	6+9+9+9+18	
					12+12+12	9+9+9+24	6+9+9+9+24 6+9+9+12+12	
					12+12+18	9+9+12+18	6+9+9+12+18	
					12+12+24	9+9+12+24	6+9+9+12+24	
			3		12+12+30 12+12+36	9+9+18+18	6+9+9+18+18 6+9+9+18+24	
					12+12+36	9+12+12+12	6+9+12+12+12	
					12+18+24	9+12+12+18	6+9+12+12+18	
					12+18+30	9+12+12+24	6+9+12+12+24	
					12+18+36 18+18+18	9+12+18+18	6+9+12+18+18	
	When there				18+18+24	9+12+18+24 9+18+18+18	6+9+12+18+24 6+9+18+18+18	
	One Way Cassette in the combination:					12+12+12+12	6+12+12+12+12	
	Wall mounted:					12+12+12+18	6+12+12+12+18	
	6K/9K/12K/18K/24K/30K/36K;					12+12+12+24	6+12+12+12+24 6+12+12+18+18	
	Cassette/One Way Cassette/					12+12+18+24	6+12+18+18+18	
	Low-static Duct/Console/	/				12+18+18+18	9+9+9+9+9	
	Floor Ceiling: 6K/9K/12K/18K/24K;	,					9+9+9+9+12	
	014 014 1214 1014 2414,						9+9+9+9+18	
	High-static duct:						9+9+9+12+12	
	9K/12K (should be considered as 18K):						9+9+9+12+18	
	18K/24K						9+9+9+12+24 9+9+9+18+18	
	(should be considered as 24K);			-			9+9+9+18+24	
							9+9+12+12+12	
			2				9+9+12+12+18	
			-				9+9+12+12+24	
				_			9+9+12+18+24	
							9+9+18+18+18	
							9+12+12+12+12	
							9+12+12+12+18 9+12+12+12+24	
							9+12+12+18+18	
					=		12+12+12+12+12	
				-	-		12+12+12+12+18	
				_			12+12+12+12+24	
			30	6+18	6+6+18	6+6+6+18	6+6+6+6+18	6+6+6+6+6+18
			36	6+24	6+6+24	6+6+6+24	6+6+6+6+24	6+6+6+6+9+18
				6+30 6+36	6+6+30 6+6+36	6+6+9+18	6+6+6+12+18	6+6+6+9+9+18
	When there			9+18	6+9+18	6+6+9+24 6+6+12+18	6+6+6+12+24 6+9+9+9+18	6+9+9+9+9+18
	AHU in the combination: Wall mounted:			9+24	6+9+24	6+6+12+24	6+9+9+9+24	9+9+9+9+9+18
моенх-	6K/9K/12K/18K/24K/30K/36K;			9+30	6+9+30	6+9+9+18	6+9+9+12+18	
H48B-2A				9+36	6+9+36	6+9+9+24	6+9+9+12+24	
мобнх-	Cassette/Low-static Duct/ Console/Floor Ceiling;			12+18 12+24	6+12+18 6+12+24	6+9+12+18 6+9+12+24	6+9+12+12+18 6+9+12+12+24	
H60B-24	6K/9K/12K/18K/24K;			12+30	6+12+30	6+12+12+18	6+12+12+12+18	
rive 6		/		12+36	6+12+36	6+12+12+24	9+9+9+9+18	
	High-static duct: 9K/12K			18+18	9+9+18	9+9+9+18	9+9+9+9+24	
	(should be considered as 18K);			18+24	9+9+24	9+9+9+24 9+9+12+18	9+9+9+12+24 9+9+9+12+18	
	18K/24K			18+36	9+9+36	9+9+12+24	9+9+12+12+18	
	(should be considered as 24K);			24+24	9+12+18	9+12+12+18	9+12+12+12+18	
	AHU:			24+30	9+12+24	9+12+12+24		
	18K/24K/30K/36K			24+36	9+12+30 9+12+36	12+12+12+18	90	
					12+12+18	12.12.12.24	100	
					12+12+24			
			70	6110	12+12+30	61616140	616161610	
			30 36	6+18 6+24	6+6+18 6+6+24	6+6+6+18 6+6+6+24	6+6+6+6+18 6+6+6+6+24	
	Miles and Alexander			6+30	6+6+30	6+6+9+18	6+6+6+12+18	
	When there One Way Cassette and AHU			6+36	6+6+36	6+6+9+24	6+6+6+12+24	
	both in the combination:		_	9+18	6+9+18	6+6+12+18	6+9+9+9+18	
	Wall mounted; 6K/9K/12K/18K/24K/30K/36K;			9+24	6+9+24	6+6+12+24 6+9+9+18	6+9+9+12+18	
	3N/3N/12N/10N/24K/3UK/36K;			9+36	6+9+36	6+9+9+24	6+9+9+12+24	
	Cassette/One Way Cassette/			12+18	6+12+18	6+9+12+18	6+9+12+12+18	
	Low-static Duct/Console/ Floor Ceiling:			12+24	6+12+24	6+9+12+24	6+9+12+12+24	
	6K/9K/12K/18K/24K;	/		12+30	6+12+30 6+12+36	6+12+12+18 6+12+12+24	6+12+12+12+18 9+9+9+9+18	
				18+18	9+9+18	9+9+9+18	9+9+9+9+24	
	High-static duct; 9K/12K			18+24	9+9+24	9+9+9+24	9+9+9+12+24	
	(should be considered as 18K);		_	18+30	9+9+30	9+9+12+18	9+9+9+12+18	
	18K/24K		_	18+36 24+24	9+9+36 9+12+18	9+9+12+24 9+12+12+18	9+9+12+12+18 9+12+12+12+18	
	(should be considered as 24K);			24+24	9+12+24	9+12+12+24	U-12-12-10	
	AHU:			24+36	9+12+30	12+12+12+18		
	18K/24K/30K/36K		2		9+12+36	12+12+12+24		
					12+12+18			
		<u> </u>			12+12+30			
			18	9+9	9+9+9	9+9+9+9	9+9+9+9+9	
			24	9+12	9+9+12	9+9+9+12	9+9+9+9+12	
				9+18	9+9+18	9+9+9+18	9+9+9+12+12 9+9+12+12+12	
				12+12	9+12+12	9+9+12+12	9+12+12+12+12	
				12+18	9+12+18	9+9+12+18	12+12+12+12+12	
				12+24	9+12+24	9+9+12+24		
			_	18+18 18+24	9+18+18 9+18+24	9+9+18+18 9+9+18+24		
	High-static duct(Only):	Ducted: 9+9+12+12+12		24+24	9+24+24	9+12+12+12	·	
	9K/12K/18K/24K	3+3+12+12+12			12+12+12	9+12+12+18		
					12+12+18	9+12+12+24		
					12+12+24	9+12+18+18 9+12+18+24		
					12+18+18	12+12+12+12		
					12+24+24	12+12+12+18		
						12+12+12+24	-	

^{4.} For AHU series:

a, The AHU fan will stop (follow me On) or run intermittently (follow me Off) when it reaches the set temperature;

b, When connected to a third-party thermostat via 24V, if the AHU has no active heating demand, the thermostat's fan-ON command will be ignored.

c, The system will start operating when the AHU receives an emergency heating demand.

Multi-Zone Outdoor Unit **Extreme Heat**

(Matched with Non-Ducted)

	•

	Indoor Unit		All Easy Pro(6K*3)	All Easy Pro(6K*3+9K)	All Easy Pro(6K*3+9K*2)	All Easy Pro(9K*4+12K)	All Easy Pro(6K*3+9K+24K)
Model	Outdoor Unit		MO3HX-H18B-2A	MO4HX-H27B-2A	MO5HX-H36B-2A	MO6HX-H48B-2A	MO6HX-H60B-2A
	AHRI Reference Number		215471457	215471460	215471463	215471466	215471469
System			3 Zone	4 Zone	5 Zone	6 Zone	6 Zone
Performance							
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
	Cooling/Heating Capacity	Btu/h	19,000/20,000	27,000/27,000	36,000/36,000	47,000/49,000	51,000/55,000
SEER2	SEER2	Btu/w	25	23	23	23	22.2
(AHRI 210/240 - 2023)	EER2	Btu/w	15	12.5	13	12	12
	HSPF4	Btu/w	10.4	10.5	10.7	11	10.5
Heating at 5°F	Rated capacity	Btu/h	19,000	27,000	36,000	47,000	47,000
(-15°C)	СОР	W/W	2	2	2	2	2
Outdoor Air Flow Volume	Max	CFM	2131	2148	3037	4503	4503
Noise Level		dB(A)	62	61	65	65	65
Outdoor unit							
Not Discossion	$W \times D \times H$	mm	946×410×810	946×410×810	980×415×975	952×415×1333	952×415×1333
Net Dimension	W×D×H	inch	37-1/4×16-1/8×31-7/8	37-1/4×16-1/8×31-7/8	38-5/8×16-3/8×38-3/8	37-1/2×16-3/8×52-1/2	37-1/2×16-3/8×52-1/2
Packing	$W \times D \times H$	mm	1090×500×885	1090×500×885	1145×500×1080	1095×495×1480	1095×495×1480
Dimension	W×D×H	inch	42-7/8×19-5/8×34-7/8	42-7/8×19-5/8×34-7/8	45-1/8×19-5/8×42-1/2	43-1/8×19-1/2×58-1/4	43-1/8×19-1/2×58-1/4
Net/Gross		kg	62.3/67.2	76.4/81.5	96.1/111	111.8/125.5	111.8/125.5
Weight		lbs	137/148	168/180	212/245	246/277	246/277

Multi-Zone Outdoor Unit Advanced Heat

(Matched with Non-Ducted)



	Indoor Unit		All Easy Pro(6K*3)	All Easy Pro(6K*3+9K)	All Easy Pro(6K*3+9K*2)	All Easy Pro(9K*4+12K)	All Easy Pro(9K*4+24K)	
Model	Outdoor Unit		MO3EX-H18B-2A	MO4EX-H27B-2A	MO5EX-H36B-2A	MO6EX-H48B-2A	MO6EX-H60B-2A	
	AHRI Reference Number		215471472	215471445	215471448	215471451	215471454	
System			3 Zone	4 Zone	5 Zone	6 Zone	6 Zone	
Performance								
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	
	Cooling/Heating Capacity	Btu/h	18,000/19,000	27,000/27,000	36,000/37,000	47,000/48,000	60,000/60,000	
SEER2	SEER2	Btu/w	25.1	25	24	24	22	
(AHRI 210/240 - 2023)	EER2	Btu/w	14	13	12	12.5	10	
	HSPF4	Btu/w	9.8	9.5	9.5	10.3	9.5	
Heating at 5°F	Rated capacity	Btu/h	13,500	19,000	26,000	36,000	39,000	
(-15°C)	СОР	W/W	2.3	2	2	2	2.2	
Outdoor Air Flow Volume	Max	CFM	1766	2131	2148	4503	4503	
Noise Level		dB(A)	60	61	65	63	65	
Outdoor unit								
Net Dimension	W×D×H	mm	890×342×673	946×410×810	946×410×810	952×415×1333	952×415×1333	
Net Dimension	W×D×H	inch	35×13-1/2×26-1/2	37-1/4×16-1/8×31-7/8	37-1/4×16-1/8×31-7/8	37-1/2×16-3/8×52-1/2	37-1/2×16-3/8×52-1/2	
Packing	W×D×H	mm	1030×438×750	1090×500×885	1090×500×885	1095×495×1480	1095×495×1480	
Dimension	W×D×H	inch	40-1/2×17-1/4×29-1/2	43×19-5/8×34-7/8	43×19-5/8×34-7/8	43-1/8×19-1/2×58-1/4	43-1/8×19-1/2×58-1/4	
Net/Gross		kg	45.6/49.6	63.0/67.9	76.6/81.7	100.7/115.3	107.9/122.6	
Weight		lbs	101/109	139/150	169/180	222/254	238/270	

Multi-Zone Outdoor Unit **Extreme Heat**

(Matched with Ducted)



	Indoor Unit		Duct(6K*3)	Duct(6K*3+9K)	Duct(6K*3+9K*2)	Duct(9K*4+12K)	Duct(6K*2+9K*2+24K)
Model	Outdoor Unit		MO3HX-H18B-2A	MO4HX-H27B-2A	MO5HX-H36B-2A	MO6HX-H48B-2A	MO6HX-H60B-2A
	AHRI Reference Number		215471458	215471461	215471464	215471467	215471470
System			3 Zone	4 Zone	5 Zone	6 Zone	6 Zone
Performance							
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
	Cooling/Heating Capacity	Btu/h	19,000/20,000	28,000/28,000	36,000/36,000	47,000/48,000	53,000/55,000
SEER2	SEER2	Btu/w	20	19	19.4	20.4	20
(AHRI 210/240 - 2023)	EER2	Btu/w	13	12	12	11.7	11.7
	HSPF4	Btu/w	10	9.5	10.4	11	10.7
Heating at 5°F	Rated capacity	Btu/h	18,000	27,000	38,000	48,000	48,000
(-15°C)	COP	W/W	2	2	2	2	2.1
Outdoor Air Flow Volume	Max	CFM	2131	2148	3037	4503	4503
Noise Level		dB(A)	62	61	65	65	65
Outdoor unit							
Net Dimension	W×D×H	mm	946×410×810	946×410×810	980×415×975	952×415×1333	952×415×1333
Net Differsion	W×D×H	inch	37-1/4×16-1/8×31-7/8	37-1/4×16-1/8×31-7/8	38-5/8×16-3/8×38-3/8	37-1/2×16-3/8×52-1/2	37-1/2×16-3/8×52-1/2
Packing	W×D×H	mm	1090×500×885	1090×500×885	1145×500×1080	1095×495×1480	1095×495×1480
Dimension	W×D×H	inch	42-7/8×19-5/8×34-7/8	42-7/8×19-5/8×34-7/8	45-1/8×19-5/8×42-1/2	43-1/8×19-1/2×58-1/4	43-1/8×19-1/2×58-1/4
Net/Gross		kg	62.3/67.2	76.4/81.5	96.1/111	111.8/125.5	111.8/125.5
Weight		lbs	137/148	168/180	212/245	246/277	246/277

Multi-Zone Outdoor Unit Advanced Heat

(Matched with Ducted)



	Indoor Unit		Duct(6K*3)	Duct(6K*3+9K)	Duct(6K*3+9K*2)	Duct(9K*5)	Duct(9K*4+24K)
Model	Outdoor Unit		MO3EX-H18B-2A	MO4EX-H27B-2A	MO5EX-H36B-2A	MO6EX-H48B-2A	MO6EX-H60B-2A
	AHRI Reference Number		215471473	215471446	215471449	215471452	215471455
System			3 Zone	4 Zone	5 Zone	6 Zone	6 Zone
Performance							
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
	Cooling/Heating Capacity	Btu/h	18,000/19,000	26,600/26,600	35,000/37,000	45,000/47,000	60,000/60,000
SEER2	SEER2	Btu/w	20	21	20	20.4	18
(AHRI 210/240 - 2023)	EER2	Btu/w	12.0	12.0	11.7	12.0	10.0
	HSPF4	Btu/w	10	9	9.2	10.6	9.2
Heating at 5°F	Rated capacity	Btu/h	14,600	18,800	26,000	38,000	40,000
(-15°C)	СОР	W/W	2.3	2	2	2.1	2.1
Outdoor Air Flow Volume	Max	CFM	1766	2131	2148	4503	4503
Noise Level		dB(A)	59	61	63	63	64
Outdoor unit							
Net Dimension	$W \times D \times H$	mm	890×342×673	946×410×810	946×410×810	952×415×1333	952×415×1333
Net Dimension	$W \times D \times H$	inch	35 x 13-1/2 x 26-1/2	37-1/4×16-1/8×31-7/8	37-1/4×16-1/8×31-7/8	37-1/2×16-3/8×52-1/2	37-1/2×16-3/8×52-1/2
Packing	$W \times D \times H$	mm	1030×438×750	1090×500×885	1090×500×885	1095×495×1480	1095×495×1480
Dimension	W×D×H	inch	40-1/2 x 17-1/4 x 29-1/2	43×19-5/8×34-7/8	43×19-5/8×34-7/8	43-1/8×19-1/2×58-1/4	43-1/8×19-1/2×58-1/4
Net/Gross		kg	45.6/49.6	63.0/67.9	76.6/81.7	100.7/115.3	107.9/122.6
Weight		lbs	101/109	139/150	169/180	222/254	238/270

Multi-Zone Indoor Unit **Air Handling Unit**



Model	Indoo	r Unit	MACHU-H18B-2A	MACHU-H24B-2A	MACHU-H30B-2A	MACHU-H36B-2A
Performance						
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	618/577/530/489/489	618/577/530/489/489	989/895/806/712/712	1189/1083/971/865/865
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	42 /42 / 40 / 33 / 33	44 / 44 / 42 / 29 / 29	44 / 44 / 41 / 26 / 26	48 / 48 / 45 / 31 /31
Indoor unit						
Net Dimension	$W \times D \times H$	mm	445×534×1143	445×534×1143	534×534×1245	534×534×1245
Net Dimension	$W \times D \times H$	inch	17-1/2×21×45	17-1/2×21×45	21×21×49	21×21×49
Danking Dimension	$W \times D \times H$	mm	530×675×1235	530×675×1235	620×675×1335	620×675×1335
Packing Dimension	$W \times D \times H$	inch	20-7/8×26-5/8×48-5/8	20-7/8 x 26-5/8 x 48-5/8	24-3/8×26-5/8×52-1/2	24-3/8×26-5/8×52-1/2
Not/Gross Meight		kg	47.5/57	47.3/57.1	57.8/68.8	58/70
Net/Gross Weight		lbs	105/126	104/126	127/152	128/154
Dining Cito	Liquid side	inch	1/4	3/8	3/8	3/8
Piping Size	Gas side	inch	1/2	5/8	5/8	5/8

Multi-Zone Indoor Unit **High Static Slim Duct**



Model	Indoo	r Unit	MDHHU-H09B-2A	MDHHU-H12B-2A	MDHHU-H18B-2A	MDHHU-H24B-2A
Performance						
Power Supply		V-,Hz,Ph 208/230, 1, 60		208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
Eternal Static Pressure (ESP)	Range	Pa	0-200	0-200	0-200	0-200
	Kange	In. wc.	0-0.80	0-0.80	0-0.80	0-0.80
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	344/288/231/201/122	419/350/256/216/135	706/618/530/441/441	854/706/618/500/500
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	30/30/29/28/26	33/33/31/29/26 36/36/34/32/28		40/40/37/35/30
Dimension & Weight						
Net/Gross Weight	$W \times D \times H$	mm	700×750×245	700×750×245	1000×750×245	1000×750×245
Net/ Gloss Weight	$W \times D \times H$	inch	27-1/2×29-1/2×9-5/8	27-1/2×29-1/2×9-5/8	39-3/8×29-1/2×9-5/8	39-3/8×29-1/2×9-5/8
Danking Dimonsion	$W \times D \times H$	mm	925×850×298	925×850×298	1225×860×304	1225×860×304
Packing Dimension	$W \times D \times H$	inch	36-3/8×33-1/2×11-3/4	36-3/8×33-1/2×11-3/4	48-1/4×33-7/8×12	48-1/4×33-7/8×12
Not/Gross Wordht		kg	29.1/33.5	29.1/33.5	36.2/41.4	36.5/41.7
Net/Gross Weight		lbs	64/74	64/74	80/92	80/92
Dialage Ciag	Liquid side	inch	1/4	1/4	1/4	3/8
Piping Size	Gas side	inch	3/8	3/8	1/2	5/8

Multi-Zone Indoor Unit Low Static Slim Duct



Model	Indoo	r Unit	MDLHU-H06B-2A	MDLHU-H09B-2A	MDLHU-H12B-2A	MDLHU-H18B-2A
Performance						
Power Supply	res	V-,Hz,Ph 208/230, 1, 60 208/230, 1, 60		208/230, 1, 60	208/230, 1, 60	
Eternal Static Pressure	Range	Pa	0-100	0-100	0-100	0-100
(ESP)	Range	In. wc.	0-0.40	0-0.40	0-0.40	0-0.40
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	o/Hi/Mi/Lo/Si CFM 324/265/206/147/118 324/265/		324/265/206/147/118	400/324/265/177/118	600/559/500/441/441
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A) 33/33/31/30 /22 33/33/31/30/23 36/36/35/		36/36/35/33/ 26	40/40/39/38/32	
Dimension & Weight						
Net/Gross Weight	$W \times D \times H$	mm	700×506×200	700×506×200	700×506×200	880×674×210
Net/Gross Weight	$W \times D \times H$	inch	27-1/2×19-7/8×7-7/8	27-1/2×19-7/8×7-7/8	27-1/2×19-7/8×7-7/8	34-5/8×26-1/2×8-1/4
Packing Dimension	$W \times D \times H$	mm	860×540×285	860×540×285	860×540×285	1070×725×280
Packing Dimension	$W \times D \times H$	inch	33-7/8×21-1/4×11-1/4	33-7/8×21-1/4×11-1/4	33-7/8×21-1/4×11-1/4	42-1/8×28-1/2×11
N / C		kg	17.9/21.2	17.9/21.2	17.9/21.2	24.7/30
Net/Gross Weight		lbs	39/47	39/47	39/47	55/66
Divisor Cine	Liquid side	inch	1/4	1/4	1/4	1/4
Piping Size	Gas side	inch	3/8	3/8	3/8	1/2

Multi-Zone Indoor Unit Wall-Mounted High Tier Series




Model	Indoor Unit		MSESU-H06B-2A	MSESU-H09B-2A	MSESU-H12B-2A	MSESU-H18B-2A		
Performance								
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60		
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	559/424/212/153/153	559/424/212/153/153	559/424/212/153/153	812/618/412/318/318		
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	42/42/33/23/19	42/42/33/23/19	42/42/33/23/19	55/44/39/27/16		
Dimension & Weight								
	$W \times D \times H$	mm	965×239×319	965×239×319	965×239×319	1140×275×370		
Net Dimension	$W \times D \times H$	inch	38×9-3/8×12-1/2	38×9-3/8×12-1/2	38×9-3/8×12-1/2	44-7/8×10-7/8×14-1/2		
Daaldaa Disaasias	$W \times D \times H$	mm	1045×400×325	1045×400×325	1045×400×325	1230×455×355		
Packing Dimension	$W \times D \times H$	inch	41-1/8×15-3/4×12-3/4	41-1/8×15-3/4×12-3/4	41-1/8×15-3/4×12-3/4	48-3/8×17-7/8×14		
Not /Cus os NA/sisslet		kg	12.8/16.7	12.8/16.7	12.8/16.7	19.8/25.2		
Net/Gross Weight		lbs	28/37	28/37	28/37	44/56		
Dining Cina	Liquid side	inch	1/4	1/4	1/4	3/8		
Piping Size	Gas side	inch	3/8	3/8	3/8	5/8		

Multi-Zone Indoor Unit Wall-Mounted All Easy Pro



Model	Indoor Unit		MSEHU-H06B-2A	MSEHU-H09B-2A	MSEHU-H12B-2A	MSEHU-H18B-2A	MSEHU-H24B-2A	MSEEU-H30B-2A	MSEHU-H33B-2A	MSEEU-H36B-2A	
Performance											
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	383/324/230/177/147	441/324/230/177/147	441/324/230/177/147	636/500/359/294/294	812/618/412/318/318	883/636/506/383/383	812/618/412/318/318	883/636/506/383/38	
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	44/37/33/22/20	38/38/33/21/20	47/37/33/22/20	50/45/38/31/20	55/44/39/27/16	53/46/40/31/20	55/44/39/27/16	49/49/44/35/32	
Dimension & Weig	imension & Weight										
Not Disconsion	$W \times D \times H$	mm	795×225×295	795×225×295	795 x 225 x 295	965×239×319	1140×275×370	1140×275×370	1140×275×370	1140×275×370	
Net Dimension	$W \times D \times H$	inch	31-3/8×8-7/8×11-5/8	31-3/8×8-7/8×11-5/8	31-3/8 x 8-7/8 x 11-5/8	38×9-3/8×12-1/2	44-7/8×10-7/8×14-1/2	44-7/8×10-7/8×14-1/2	44-7/8×10-7/8×14-1/2	44-7/8×10-7/8×14-1/2	
Davidson Disconsider	$W \times D \times H$	mm	920×310×370	920×310×370	920 x 310 x 370	1095×325×400	1280×360×455	1280×360×455	1280×360×455	1280×360×455	
Packing Dimension	$W \times D \times H$	inch	36-1/4×12-1/4×14-5/8	36-1/4×12-1/4×14-5/8	36-1/4 x 12-1/4 x 14-5/8	43-1/8×12-3/4×15-3/4	50-3/8×14-1/8×17-7/8	50-3/8×14-1/8×17-7/8	50-3/8×14-1/8×17-7/8	50-3/8×14-1/8×17-7/8	
Not/Green Meint		kg	10.4/13.3	10.6/13.6	10.4/13.3	12.4/16.6	19.8/25.2	19.6/24.8	19.6/25.3	19.6/24.8	
Net/Gross Weight		lbs	23/29	23/30	23/29	27/37	44/56	43/55	43/56	43/55	
Dining Circ	Liquid side	inch	1/4	1/4	1/4	1/4	3/8	3/8	3/8	3/8	
Piping Size	Gas side	inch	3/8	3/8	3/8	1/2	5/8	5/8	3/4	5/8	

Multi-Zone Indoor Unit Wall-Mounted INFINI





Multi-Zone Indoor Unit One-Way Cassette



Model	Indoor Unit		MCAHU-H06B-2A	MCAHU-H09B-2A	MCAHU-H12B-2A	MCAHU-H18B-2A
Performance						
Power Supply		V, Ph, Hz	208/230V,1Ph, 60Hz	208/230V,1Ph, 60Hz	208/230V,1Ph, 60Hz	208/230V,1Ph, 60Hz
Air Flow Volume	Turbo/Hi/Mi/Lo/Si	CFM	341/294/259/235/235	341/294/259/235/235	353/312/283/247/177	400/352/300/207/207
Noise Level	Turbo/Hi/Mi/Lo/Si	dB(A)	47/38/36/26/24	38/38/36/33/24	41/41/37/33/24	44/44/42/31/26
Dimension & Weight						
Net Dimension	$W \times D \times H$	mm	1278×335×228	1278×335×228	1278×335×228	1278×335×228
	$W \times D \times H$	inch	50-1/4×13-1/4×9	50-1/4×13-1/4×9	50-1/4×13-1/4×9	50-1/4×13-1/4×9
Packing Dimension	$W \times D \times H$	mm	1463×571×575	1463×571×575	1463×571×575	1463×571×575
	$W \times D \times H$	inch	57-5/8×22-1/2×22-5/8	57-5/8×22-1/2×22-5/8	57-5/8×22-1/2×22-5/8	57-5/8×22-1/2×22-5/8
Net/Gross Weight		kg	20.5/37.4	20.5/37.4	20.5/37.4	20.5/37.6
		lbs	45/82	45/82	45/82	45/82
Piping Size	Liquid side	inch	1/4	1/4	1/4	1/4
	Gas side	inch	3/8	3/8	3/8	1/2

Multi-Zone Indoor Unit Compact Cassette



Model	Indoor Unit		MCDHU-H09B-2A	MCDHU-H12B-2A	MCDHU-H18B-2A	MCDHU-H24B-2A
Performance						
Power Supply		V, Ph, Hz	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60	208/230, 1, 60
Air Flow Volume	H/M/L	CFM	353/312/265/183/147	418/365/306/194/147	447/389/318/194/147	765/706/636/547/547
Noise Level	H/M/L	dB(A)	43/40/38/26/24	46/43/40/28/26	48/45/41/28/24	49/45/43/34/34
Indoor unit						8
Net Dimension	$W \times D \times H$	mm	570×570×245	570×570×245	570×570×245	830×830×205
	$W \times D \times H$	inch	22-1/2×22-1/2×9-5/8	22-1/2×22-1/2×9-5/8	22-1/2×22-1/2×9-5/8	32-5/8×32-5/8×8-1/8
Packing Dimension	$W \times D \times H$	mm	715×640×295	715×640×295	715×640×295	910×910×250
	$W \times D \times H$	inch	28-1/8×25-1/4×11-5/8	28-1/8×25-1/4×11-5/8	28-1/8×25-1/4×11-5/8	35-7/8×35-7/8×9-7/8
Net/Gross Weight		kg	16/19	16.0/19.0	16.0/19.0	21.4/26.8
		lbs	35/42	35/42	35/42	47/59
Piping Size	Liquid side	inch	1/4	1/4	1/4	3/8
	Gas side	inch	3/8	3/8	1/2	5/8